

List of JWQA Q100 Performance Indicator led by Statistics on Water Supply in Japan

Guidelines for the management and assessment of a drinking water supply service (JWQA Q100)				Statistics on Water Supply	
PI Code	Name of PI	Description	Definition	Stats Code	Name of Stats
1001	Resources availability ratio	The purpose of drinking water supply services is to deliver the enough volume of water with stability. To do it, water resources should hold the sufficient volume of water. The ratio of water volume held by the water resources to water volume consumed actually represents the allowance and efficiency of the water resources. Accordingly, this indicator value should be high in preparation for droughts.	Resources availability ratio = $(\text{Average daily transmission input}/\text{Resource capacity}) \times 100$ (unit: %)	5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
				0412	Designed Maximum Water Abstraction Volume per Day/ Total (m3)
1002	Surplus capacity of resources	The purpose of drinking water supply services is to deliver the enough volume of water with stability. To do it, water resources should hold the sufficient volume of water. The ratio of water volume held by the water resources to water volume consumed actually represents the allowance and efficiency of the water resources. Accordingly, this indicator value should be high in preparation for droughts.	Surplus capacity of resources = $((\text{Resource capacity}/\text{Maximum daily transmission input}) \times 1) \times 100$ (Unit: %)	5103	Water Supply Volume per Day/ Daily Maximum Water Supply Volume (m3)
				0412	Designed Maximum Water Abstraction Volume per Day/ Total (m3)
1003	Effective raw water ratio	This indicator is similar to the leakage rate indicator, but represents the ratio of water effectively used to water abstracted. It has wider meaning than the leakage rate indicator, that is, the effectiveness of water used in terms of total system.	Effective raw water ratio = $(\text{Annual effective volume}/\text{Annual intake volume}) \times 100$ (Unit: %)	5021	Annual Water Supply Volume/ Accounted Water Consumption (1,000 m3)
				5026	Annual Bulk Water Supply Volume/ Accounted Water Consumption (1,000 m3)
				5031	Annual Water supply volume to another water supplier/ Accounted Water Consumption (1,000 m3)
				5012	Annual Water Abstraction Volume/ Total (1,000 m3)
1004	Self owned resources ratio	This indicator can be applied to self owned dams and wells, and represents flexibility in the management of water resources. In addition, it relates to water flexibility upon drought.	Self owned resources ratio = $(\text{Self owned resource capacity}/\text{Total resource capacity}) \times 100$ (Unit: %)	0412	Designed Maximum Water Abstraction Volume per Day/ Total (m3)
				0408	Designed Maximum Water Abstraction Volume per Day/ Raw Water Receiving (m3)
				0411	Designed Maximum Water Abstraction Volume per Day/ Purified Water Receiving (m3)
				0412	Designed Maximum Water Abstraction Volume per Day/ Total (m3)

1115	Direct supply from distribution main	<p>This indicator is a direct water supply ratio, and is one of indices showing the extent to which an approach to keeping the reliability of water quality control is employed and the safety of service quality. Compared with the conventional method of using receiving tanks for buildings having three floors or more, the direct water supply method has advantages, for example, it can address sanitary problems in the tank and trouble with the water quality. Accordingly, it is desired to migrate to the direct water supply method by improving water distribution systems and facilities in the future.</p>	<p>Direct supply from distribution main = (Number of direct connection users/ Total number of users) × 100 (unit: %)</p>	6981	Total/ Number of buildings
				5214	Tariff structure by customer use/ Number of Household/ Total
				5342	Tariff structure by meter size/ Number of Household/ Total
1117	Ratio of lead service lines	<p>As a rule, the use of lead pipes are prohibited from a safety point of view, but many old lead pipes still remains. Water utilities may change the type of pipes connected to water meters when making a laying change in distribution lines. However, this indicator value does not reduce because they cannot change indoor lead pipes.</p>	<p>Ratio of lead service lines = (Number of lead service lines in use/ Number of service lines) × 100 (unit: %)</p>	3907	Lead Service pipes/ Site Number of remaining Lead service pipes (Total)
				5214	Tariff structure by customer use/ Number of Household/ Total
				5342	Tariff structure by meter size/ Number of Household/ Total
2001	Drinking water storage volume per population supplied	<p>The service reservoir capacity should be high enough to keep drinking water in preparation for disasters like earthquakes. When a disaster occurs, a single user needs a minimum water volume of three liters in a day. This indicator gives information about how many days the reservoir can supply water, but in real life, three liters become insufficient over the course of time. Accordingly, this indicator employs the volume of reserved drinking water per user, not the number days.</p>	<p>Drinking water storage volume per population supplied = ((Total service reservoir capacity (except emergency reservoirs) × 1/2 + Emergency reservoir capacity)/ Service population) × 1,000 (unit: L/person)</p>	0532	Water Purification Plant/ Treated Water Reservoir/ Effective Capacity (m3)
				0542	Water Purification Plant/ Distribution Reservoir/ Effective Capacity of Distribution Reservoirs (m3)
				0535	Water Distribution Facilities/ Effective Capacity of Distribution Reservoirs (m3)
				0540	Water Distribution Facilities/ Effective Capacity of Elevated Distribution Reservoir (m3)
				6708	Emergency receiving tanks, etc./ Settled by Water utilities/ Potable Water & Domestic water (m3)
				6711	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Water Utilities/ Potable Water & Domestic water (m3)
				6714	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Local governments/ Potable Water & Domestic water (m3)
				0206	Population/ Water Supply Population (Capita)

2002	Transmission input per population supplied	This indicator shows the progress of water-saving consumption, which is an approach to the preservation of water environments.	Transmission input per population supplied = (Average daily transmission input/ Service population) × 1,000 (unit: L/person/day)	5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
				5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
				0206	Population/ Water Supply Population (Capita)
2004	Service reservoir capacity	This indicator tells how many hours the reservoirs can supply water at an average daily flow rate, that is, the stability of water supply and the capability of responding to critical events, such as disasters and accidents. The larger the indicator value, the higher the capabilities of water regulation and ad hoc water supply when an emergency event has occurred. According to Design Criteria for Waterworks Facilities, the service reservoir should have effective capacity which makes it possible to deliver water for 12 hours at a maximum daily flow rate.	Service reservoir capacity = Total service reservoir capacity/ Average daily transmission input (unit: days)	0532	Water Purification Plant/ Treated Water Reservoir/ Effective Capacity (m3)
				0542	Water Purification Plant/ Distribution Reservoir/ Effective Capacity of Distribution Reservoirs (m3)
				0535	Water Distribution Facilities/ Effective Capacity of Distribution Reservoirs (m3)
				0540	Water Distribution Facilities/ Effective Capacity of Elevated Distribution Reservoir (m3)
				6708	Emergency receiving tanks, etc./ Settled by Water utilities/ Potable Water & Domestic water (m3)
				6711	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Water Utilities/ Potable Water & Domestic water (m3)
				6714	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Local governments/ Potable Water & Domestic water (m3)
				5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
				5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)

				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
2005	Restricted water supply	This indicator represents days when water supply is restricted in a year, that is, comfort and convenience given to users as well as the stability of water supply services.	Restricted water supply = Number of restricted service days per year (unit: days)	6943	Drought/ Pressure reducing water supply/ Number of days
				6945	Drought/ Temporal water supply/ Number of days
				6948	Water quality accident/ Pressure reducing water supply/ Number of days
				6950	Water quality accident/ Temporal water supply/ Number of days
2006	Population served by water supply	This indicator represents the ratio of the number of users to the population of a service area, and is one of indices showing the general conditions and local characteristics of water supply services.	Population served by water supply = (Service population/ Service area population) × 100 (unit: %)	0206	Population/ Water Supply Population (Capita)
				0202	Population/ Population in Water Supply District (Capita)
2007	Distribution mains density	This indicator represents the length of distribution pipes per service area of 1 km ² , which means the extent of physical convenience when consumers apply for water supply.	Distribution mains density = Distribution pipe length/ Service area (unit: km/km ²)	0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
				0218	Area/ Current Water Supply District Area (km ²)
2008	Customer meter density	This indicator represents the number of water meters per pipeline of 1 km, that is, the number of water supply points per unit length of distribution pipes.	Customer meter density = Number of water meters/ Distribution pipe length (unit: No./km)	5215	Number of installed meter
				5343	Number of installed meter
				0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
2101	Aging of water treatment facilities	The useful life has a deep relationship with years for which facilities have been used. However, it is difficult to constantly review the useful life in order to maintain and control waterworks facilities. Accordingly, this indicator employs the statutory useful life defined in Municipal Enterprise Law.	Aging of water treatment facilities = (Capacity of purification facilities exceeding statutory useful life/ Capacity of all purification facilities) × 100 (unit: %)	3601	Capacity of Facilities/ Exceed Depreciation Period Designated by Law (m ³ / day)
				5118	Capacity of Facilities (m ³ / day)
2102	Aging of electric and mechanical equipment	The life cycle has a deep relationship with years for which electrical or mechanical equipment has been used. However, it is difficult to constantly review the life cycle in order to	Aging of electric and mechanical equipment = (Number of electric and mechanical equipment exceeding life cycle/ Total number of electric and	3603	Number of Instrumentation equipment exceed legal durable years (number of equipment)

		maintain and control waterworks facilities. Accordingly, this indicator employs the life cycle.	mechanical equipment) × 100 (unit: %)	3602	Total number of Instrumentation equipment (number of equipment)
2103	Aging of mains	The useful life has a deep relationship with years for which facilities have been used. However, it is difficult to constantly review the useful life in order to maintain and control waterworks facilities. Accordingly, this indicator employs the statutory useful life of pipelines.	Aging of mains = (Length of pipelines exceeding statutory useful life/ Total pipeline length) × 100 (unit: %)	3604	Length of Pipeline/ Raw Water Conveyance pipes/ pipes exceed Depreciation Period Designated by Law (40 years) (m)
				3605	Length of Pipeline/ Water Transmission pipes/ pipes exceed Depreciation Period Designated by Law (40 years) (m)
				3606	Length of Pipeline/ Distributing Main pipes/ pipes exceed Depreciation Period Designated by Law (40 years) (m)
				3607	Length of Pipeline/ Distributing Branch pipes/ pipes exceed Depreciation Period Designated by Law (40 years) (m)
				0701	Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total (m)
				0706	Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)
				0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
2104	Mains rehabilitation	This indicator represents the percentage of conveyance, transmission, and distribution pipes replaced in a year, that is, the extent to which the replacement is made in order to ensure the reliability.	Mains rehabilitation = (Length of replaced pipelines/ Total pipeline length) × 100 (unit: %)	7016	Raw Water and Purified Water Transmission pipes/ Length of Replaced pipes/ Total (m)
				7040	Water Distribution pipes/ Length of Replaced pipes/ Total (m)
				0701	Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total (m)
				0706	Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)

				0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
2106	Valves replacement	This indicator represents the percentage of valves replaced in a year, that is, the extent to which the replacement is made in order to ensure the reliability of water distribution control for pipelines.	Valves replacement = (Number of replaced valves/ Total number of existing valves) × 100 (unit: %)	0746	Number of Replaced Valve
				0747	Number of Installed Valve
2107	Newly installed mains	This indicator shows the extent to which pipelines increase. Water distribution networks should cover all service areas to achieve the 100 -percent water supply coverage.	Newly installed mains = (Length of newly installed pipelines/ Total pipeline length) × 100 (unit: %)	7008	Raw Water and Purified Water Transmission pipes/ Length of Newly Installed pipes/ Total (m)
				7032	Water Distribution pipes/ Length of Newly Installed pipes/ Total (m)
				0701	Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total (m)
				0706	Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)
				0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
2201	Accidental water resource pollution	This indicator does not relate directly to services offered by water utilities or authorities, but they should take flexible measures against any accidents to supply an enough volume of water. Most water pollution accidents have a serious impact on water supply. Accordingly, it is important to take a variety of preventive measures to reduce the accidents. Using this indicator with water cut rates allows water utilities to check the stability of drinking water supply services.	Accidental water resource pollution = Number of water pollution accidents per year (unit: No.)	3809	Annual Water quality accident/ Number of incidents (times/ year)
2202	Trunk mains failures	This indicator represents the number of accidents occurring in main pipelines in a year, that is, the soundness of the pipeline facilities. The mains refer to pipelines important to water operation. When this indicator value becomes large, water utilities should take quick measures, for example, replacement pipelines in which accidents often occur or which have aged pipes.	Trunk mains failures = (Number of mains failures/ Total mains length) × 100 (unit: No./100 km)	3810	Number of Water main pipe accidents (times/ year)
				6812	Length of Raw Water Conveyance pipes/ Total (m)
				6824	Length of Water Transmission pipes/ Total (m)

				6836	Length of Water Distribution pipes/ Distributing Main pipes/ Total (m)
2203	Available water volume in an accident	For the risk management of drinking water supply systems, it is simply assumed that the largest purification plant or pump station stops completely. This indicator represents the flexibility and margin of the system, that is, the sustainability of services.	Available water volume in an accident = $(\text{Reduced transmission input} / \text{Average daily transmission input}) \times 100$ (unit:%)	3811	Distribution water volume at the time of accidents (m ³ / day)
				5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m ³)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m ³)
2204	Population supplied water in an accident	For the risk management of drinking water supply systems, it is simply assumed that the largest purification plant or pump station stops completely. This indicator represents the flexibility and margin of the system, that is, the sustainability of services.	Population supplied water in an accident = $(\text{Accident -affected population} / \text{Service population}) \times 100$ (unit:%)	3812	Water Supply Population at the time of accidents (Capita)
				0206	Population/ Water Supply Population (Capita)
2205	Water supply points density in emergency	This indicator represents the number of service locations per service area of 100 km ² , that is, the ease of use when an emergency event has occurred. It is also one of indices showing response to an emergency event.	Water supply points density in emergency = $(\text{Number of distribution and emergency reservoirs} / \text{Service area}) \times 100$ (unit: No./100 km ²)	6701	Distribution Reservoir, etc./ Disaster correspondence/ Number of Water Supply (Number of Authorization)
				6704	Wells/ Number of Water Supply
				6707	Emergency receiving tanks, etc./ Settled by Water utilities/ Number of Water Supply
				6710	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Water Utilities/ Number of Water Supply
				6713	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Local governments/ Number of Water Supply
				0218	Area/ Current Water Supply District Area (km ²)
2207	Ratio of earthquake-resistant treatment facility	Drinking water structures should conform to earthquake resistance for safety (Rank A of Level 2). New facilities are designed to meet Level 2, while it is difficult to improve aged facilities to meet Level 2. Therefore, repairs for improving the earthquake resistance should be evaluated carefully.	Ratio of earthquake-resistant treatment facility = $(\text{Capacity of earthquake-resistant purification facilities} / \text{Capacity of all purification facilities}) \times 100$ (unit:%)	4101	Capacity of Purification plants with Earthquake-resistance/ L_2 対応 (m ³ / day)
				5118	Capacity of Facilities (m ³ / day)

2208	Ratio of earthquake-resistant pumping station	Drinking water structures should conform to earthquake resistance for safety (Rank A of Level 2). New facilities are designed to meet Level 2, while it is difficult to improve aged facilities to meet Level 2. Therefore, repairs for improving the earthquake resistance should be evaluated carefully. This indicator makes a judgment regarding the earthquake resistance of pump stations rather than pumps.	Ratio of earthquake-resistant pumping station = (Capacity of earthquake-resistant pump stations/ Capacity of all pump stations) × 100 (unit:%)	4105	Capacity of pumping stations with Earthquake-resistance ランク A で L 2 対応 (m3/ day)
				6514	Pumping Stations classified by Facilities/ Total/ Pumping Volume (m3/ min.)
2209	Ratio of earthquake-resistant service reservoir	Drinking water structures should conform to earthquake resistance for safety (Rank A of Level 2). New facilities are designed to meet Level 2, while it is difficult to improve aged facilities to meet Level 2. Therefore, repairs for improving the earthquake resistance should be evaluated carefully. In addition, the water leakage should be checked with this indicator. If a plant has pump stations and distribution reservoirs, water utilities should select either indicator by comparing the importance of both facilities.	Ratio of earthquake-resistant service reservoir = (Capacity of earthquake-resistant service reservoirs/ Capacity of all service reservoirs) × 100 (unit:%)	4109	Earthquake-resistant countermeasureが施されている Distribution Reservoir/ Capacity/ ランク A で L 2 対応 (m3)
				0532	Water Purification Plant/ Treated Water Reservoir/ Effective Capacity (m3)
				0542	Water Purification Plant/ Distribution Reservoir/ Effective Capacity of Distribution Reservoirs (m3)
				0535	Water Distribution Facilities/ Effective Capacity of Distribution Reservoirs (m3)
				0540	Water Distribution Facilities/ Effective Capacity of Elevated Distribution Reservoir (m3)
				6708	Emergency receiving tanks, etc./ Settled by Water utilities/ Potable Water & Domestic water (m3)
				6711	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Water Utilities/ Potable Water & Domestic water (m3)
				6714	Emergency receiving tanks, etc./ Settled by Local Government/ Managed by Local governments/ Potable Water & Domestic water (m3)
2210	Ratio of earthquake-resistant pipeline	This indicator shows the progress of migration to earthquake-resistant conveyance, transmission, and distribution pipes, that is, water supply system's safety and response to seismic disasters. Since not so many	Ratio of earthquake-resistant pipeline = (Length of earthquake-resistant pipelines/ Total pipeline length) × 100 (unit:%)	6802	Length of Raw Water Conveyance pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)
				6814	Length of Water Transmission pipes Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)

		<p>Polyethylene pipes are used, it still takes a time to verify the earthquake resistance. Accordingly, the performance indicator should be marked with an asterisk (*) if the polyethylene pipe is included.</p>		<table border="1"> <tr><td>6826</td><td>Length of Water Distribution pipes/ Distributing Main pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)</td></tr> <tr><td>6838</td><td>Length of Water Distribution pipes/ Distributing Branch pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)</td></tr> <tr><td>6850</td><td>Length of Raw Water Conveyance pipes/ Steel pipes (Connected with Welded Joint) (m)</td></tr> <tr><td>6854</td><td>Length of Water Transmission pipes Steel pipes (Connected with Welded Joint) (m)</td></tr> <tr><td>6858</td><td>Length of Water Distribution pipes/ Distributing Main pipes/ Steel pipes (Connected with Welded Joint) (m)</td></tr> <tr><td>6862</td><td>Length of Water Distribution pipes/ Distributing Branch pipes/ Steel pipes (Connected with Welded Joint) (m)</td></tr> <tr><td>6852</td><td>Length of Raw Water Conveyance pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)</td></tr> <tr><td>6856</td><td>Length of Water Transmission pipes Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)</td></tr> <tr><td>6860</td><td>Length of Water Distribution pipes/ Distributing Main pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)</td></tr> <tr><td>6864</td><td>Length of Water Distribution pipes/ Distributing Branch pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)</td></tr> <tr><td>6810</td><td>Length of Raw Water Conveyance pipes/ Stainless Steel pipes (m)</td></tr> <tr><td>6822</td><td>Length of Water Transmission pipes Stainless Steel pipes</td></tr> <tr><td>6834</td><td>Length of Water Distribution pipes/ Distributing Main pipes/ Stainless Steel pipes (m)</td></tr> <tr><td>6846</td><td>Length of Water Distribution pipes/ Distributing Branch pipes/ Stainless Steel pipes (m)</td></tr> <tr><td>0701</td><td>Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total</td></tr> <tr><td>0706</td><td>Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)</td></tr> <tr><td>0711</td><td>Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)</td></tr> </table>	6826	Length of Water Distribution pipes/ Distributing Main pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)	6838	Length of Water Distribution pipes/ Distributing Branch pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)	6850	Length of Raw Water Conveyance pipes/ Steel pipes (Connected with Welded Joint) (m)	6854	Length of Water Transmission pipes Steel pipes (Connected with Welded Joint) (m)	6858	Length of Water Distribution pipes/ Distributing Main pipes/ Steel pipes (Connected with Welded Joint) (m)	6862	Length of Water Distribution pipes/ Distributing Branch pipes/ Steel pipes (Connected with Welded Joint) (m)	6852	Length of Raw Water Conveyance pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)	6856	Length of Water Transmission pipes Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)	6860	Length of Water Distribution pipes/ Distributing Main pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)	6864	Length of Water Distribution pipes/ Distributing Branch pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)	6810	Length of Raw Water Conveyance pipes/ Stainless Steel pipes (m)	6822	Length of Water Transmission pipes Stainless Steel pipes	6834	Length of Water Distribution pipes/ Distributing Main pipes/ Stainless Steel pipes (m)	6846	Length of Water Distribution pipes/ Distributing Branch pipes/ Stainless Steel pipes (m)	0701	Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total	0706	Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)	0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
6826	Length of Water Distribution pipes/ Distributing Main pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)																																					
6838	Length of Water Distribution pipes/ Distributing Branch pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)																																					
6850	Length of Raw Water Conveyance pipes/ Steel pipes (Connected with Welded Joint) (m)																																					
6854	Length of Water Transmission pipes Steel pipes (Connected with Welded Joint) (m)																																					
6858	Length of Water Distribution pipes/ Distributing Main pipes/ Steel pipes (Connected with Welded Joint) (m)																																					
6862	Length of Water Distribution pipes/ Distributing Branch pipes/ Steel pipes (Connected with Welded Joint) (m)																																					
6852	Length of Raw Water Conveyance pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)																																					
6856	Length of Water Transmission pipes Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)																																					
6860	Length of Water Distribution pipes/ Distributing Main pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)																																					
6864	Length of Water Distribution pipes/ Distributing Branch pipes/ Polyethylene pipes (Connected with Reinforced Heat Fusion Attachment pipes Fittings) (m)																																					
6810	Length of Raw Water Conveyance pipes/ Stainless Steel pipes (m)																																					
6822	Length of Water Transmission pipes Stainless Steel pipes																																					
6834	Length of Water Distribution pipes/ Distributing Main pipes/ Stainless Steel pipes (m)																																					
6846	Length of Water Distribution pipes/ Distributing Branch pipes/ Stainless Steel pipes (m)																																					
0701	Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total																																					
0706	Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)																																					
0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)																																					
2211	Chemicals stock	Each purification plant has to keep chemicals for water treatment. An earthquake may make it impossible to deliver chemicals. Accordingly, it is desired to have appropriate amounts of chemical stocks.	Chemicals stock = Average chemical stock/ Daily consumption (unit: days)	<table border="1"> <tr><td>4205</td><td>Chemical Storage/ Average Coagulant Storage (t)</td></tr> <tr><td>4242</td><td>Chemical Storage/ Average Chlorine Agent Storage (t)</td></tr> </table>	4205	Chemical Storage/ Average Coagulant Storage (t)	4242	Chemical Storage/ Average Chlorine Agent Storage (t)																														
4205	Chemical Storage/ Average Coagulant Storage (t)																																					
4242	Chemical Storage/ Average Chlorine Agent Storage (t)																																					

				4206	Chemical Storage/ Daily Average Coagulant Usage Volume (t/ day)
				4243	Chemical Storage/ Daily Average Chlorine Agent Usage Volume (t/ day)
2212	Fuel stock	Each purification plant has to keep fuels. An earthquake may make it impossible to deliver fuels. Accordingly, it is desired to have appropriate amounts of fuel stocks able to supply power for a period of time assumed in the event of a disaster.	Fuel stock = Average fuel stock/ Daily consumption (unit: days)	4207	Fuel storage/ Average Fuel storage volume (t)
				4208	Fuel storage/ Daily Water Consumption (t/ day)
2213	Water truck	The more the supplies, the more helpful in an emergency event, but cost and control problems persist. The necessary supplies include engine pumps, lamps, water balloons, water bags, and simple purifiers, but this indicator selects only emergency water trucks as their representative.	Water truck = (Number of water trucks/ Service population) × 1,000 (unit: No./1,000 persons)	4211	Number of Water trucks (台)
				0206	Population/ Water Supply Population (Capita)
2215	Water service tank carried by vehicles	This indicator represents how much water can be supplied to 1,000 users via on-vehicle service tanks in the event of a disaster, that is, response to critical events such as earthquakes.	Water service tank carried by vehicles = (Total capacity of on - vehicle service tanks/ Service Population) × 1,000 (unit: m3/1,000 persons)	4212	Total Capacity of Water service tanks for car (m3)
				0206	Population/ Water Supply Population (Capita)
2216	Ratio of non-utility generation facility	The indicator is the ratio of on-site generation power to total generation power in waterworks facilities, and shows the percentage of electric facilities able to run in an emergency event, that is, one of indices representing response to critical events.	Ratio of non-utility generation facility = (On-site generation power/ Total generation power) × 100 (unit:%)	4209	Capacity of Non-utility generation facilities (kW)
				4210	Total Electric Power Capacity of Non-utility generation facilities (kW)
3001	Operating ratio	This indicator is one of indices showing the profitability. It indicates the extent to which the income covers the expense. The higher the operating ratio, the higher the profit, and less than 100 percent means a loss	Operating ratio = (Operating income/ Operating expenses) × 100 (unit:%)	5402	(1) Operating Income [(a)~ (c)] (1,000 yen)
				5413	(1) Operating Expenses [(a)~ (j)] (1,000 yen)
3002	Ratio of current expense to current income	This indicator is the most typical index showing the profitability. It indicates the extent to which the income covers the expense. The higher the ratio, the higher the current profit, and less than 100 percent means a loss. The operation is good if this indicator exceeds 100 percent within a charge calculating period (financial planning period) rather than in one fiscal year.	Ratio of current expense to current income = ((Operating income + Non-operating income)/ (Operating expenses + Non-operating expenses)) × 100 (unit: %)	5402	(1) Operating Income [(a)~ (c)] (1,000 yen)
				5406	(2) Non-operating Income [(a)~ (d)] (1,000 yen)
				5413	(1) Operating Expenses [(a)~ (j)] (1,000 yen)

				5424	(2) Non-operating Expenses [(a)~(e)] (1,000 yen)
3003	Rate of total returns	This indicator shows the extent to which the gross income covers the gross expense. The operation is not good if the indicator value does not exceed 100 percent, which means that the income is less than the expense.	Rate of total returns = (Gross income/ Gross expenses) × 100 (unit:%)	5401	1 / Gross Income (1)+(2)+(3) (1,000 yen)
				5412	2 / Gross Expenses (1)+(2)+(3) (1,000 yen)
3004	Ratio of cumulative deficit	This indicator is the ratio of the cumulative deficit to the operating income (except the commissioned work revenue), and shows whether the operation of a water utility is good or not by grasping the amount of the cumulative deficits. It is one of indices showing the soundness of operation. If the indicator is not zero, it says that the operation is not good. The higher the value, the worse the operation.	Ratio of cumulative deficit = (Cumulative deficit/ (Operating income × Commissioned work income)) × 100 (unit:%)	5535	(c) Unappropriated Profit, Unappropriated Deficit (Δ) (1,000 yen)
				5402	(1) Operating Income [(a)~(c)] (1,000 yen)
				5404	(b) Revenue on Trusted Construction (1,000 yen)
3005	Percentage of money transferred (revenue receipts)	This indicator represents the dependence of the revenue receipts on the transferred money, that is, the soundness and efficiency of operation. Drinking water supply services are based on a self-supporting system in which the source of revenue is a water rate. It is desirable to make the indicator value lower.	Percentage of money transferred (revenue receipts) = (Transferred money/ Revenue receipts) × 100 (unit:%)	5409	(c) Subsidy from General Account (1,000 yen)
				5401	1 / Gross Income (1)+(2)+(3) (1,000 yen)
3006	Percentage of money transferred (capital income)	This indicator represents the dependence of the capital income on the transferred money, and is one of indices showing the soundness and efficiency of operation. Drinking water supply services are based on a self-supporting system in which the source of revenue is a water rate. It is desirable to make the indicator value lower.	Percentage of money transferred (capital income) = (Transferred money on capital accounts/ Capital income) × 100 (unit:%)	5606	1 / Capital Receipt (2) Subsidies from General Account (1,000 yen)
				5608	1 / Capital Receipt (4) Government Subsidy (1,000 yen)
				5611	1 / Capital Receipt (7)/ Total [(1)~(6)] (A) (1,000 yen)
3007	Revenue on water sales per personnel	This indicator employs the water supply revenue to represent productivity per staff member belonging to the profit and loss account.	Revenue on water sales per personnel = (Water supply revenue/ Number of staff members on profit and loss account)/ 1,000 (unit: thousand yen/person)	5403	(a) Revenue on Water Supply (1,000 yen)
				0330	Number of Personnel which accounted to profit & loss account (Capita)

3008	Ratio of personnel salary costs for revenue on water sales	This indicator represents the ratio of the salaries paid to the personnel to the water supply revenue, and is one of indices used to analyze the profitability of operation. Basically, the water supply revenue should go to drinking water supply services, so it is not desirable to increase the indicator value by allotting the revenue to the personnel.	Ratio of personnel salary costs for revenue on water sales = $(\text{Labor cost} / \text{Water supply revenue}) \times 100$ (unit:%)	5732	1/ Personnel Expenses [(1)+(2)] (1,000 yen)
				5403	(a) Revenue on Water Supply (1,000 yen)
3009	Ratio of income bond interest for revenue on water sales	This indicator represents the ratio of the interest on corporate bonds to the water supply revenue, and is one of indices used to analyze the profitability of operation.	Ratio of income bond interest for revenue on water sales = $(\text{Interest on corporate bonds} / \text{Water supply revenue}) \times 100$ (unit :%)	5425	(a) Interest Cost of Public Corporation Bonds (1,000 yen)
				5403	(a) Revenue on Water Supply (1,000 yen)
3010	Ratio of depreciation cost for revenue on water sales	This indicator represents the ratio of the depreciation costs to the water supply revenue, and is one of indices used to analyze the profitability of operation.	Ratio of depreciation cost for revenue on water sales = $(\text{Depreciation cost} / \text{Water supply revenue}) \times 100$ (unit:%)	5421	(h) Depreciation Expense (1,000 yen)
				5403	(a) Revenue on Water Supply (1,000 yen)
3011	Ratio of principal redemption on revenue bond for revenue on water sales	This indicator represents the ratio of the money redeemed from corporate bonds to the water supply revenue, and is used to analyze the impact of the redemption money on operation.	Ratio of principal redemption on revenue bond for revenue on water sales = $(\text{Redemption money} / \text{Water supply revenue}) \times 100$ (unit:%)	5617	2 / Capital Expenditure (3) Redemption of Public Corporation Bonds (1,000 yen)
				5403	(a) Revenue on Water Supply (1,000 yen)
3012	Ratio of unamortized balance on revenue bond for revenue on water sales	This indicator represents the ratio of the balance of corporate bonds to the water supply revenue, and is used to analyze the corporate bond balance and its impact on operation.	Ratio of unamortized balance on revenue bond for revenue on water sales = $(\text{Corporate bond balance} / \text{Water supply revenue}) \times 100$ (unit:%)	5523	(2) Borrowed Capital [(a)~(b)] (1,000 yen)
				5403	(a) Revenue on Water Supply (1,000 yen)
3013	Ratio of tariff to production (ratio of water supply charges to water supply expenses)	This indicator represents the balance of water supply, and is one of indices showing the soundness of operation. If the indicator value is below 100 percent, income other than charges compensates water supply expenses.	Ratio of tariff to production = $(\text{Water supply rate} / \text{Water supply cost}) \times 100$ (unit:%)		
3014	Unit tariff of water supply	This indicator shows how much money water utilities earn by supplying a cubic meter of drinking water.	Unit tariff of water supply = $(\text{Water supply revenue} / \text{Revenue water volume}) \times 100$ (unit:yen/m ³)	5403	(a) Revenue on Water Supply (1,000 yen)

			VOLUME) × 100 (unit: yen/m ³)	5022	Annual Water Supply Volume/ Breakdown/ Billed Water Consumption (1,000 m ³)
				5027	Annual Bulk Water Supply Volume/ Breakdown/ Billed Water Consumption (1,000 m ³)
				5032	Annual Water supply volume to another water supplier/ Breakdown/ Billed Water Consumption (1,000 m ³)
3015	Cost to water supply	This indicator shows how much money water utilities pay for supplying a cubic meter of revenue water.	Cost to water supply = (Ordinary expenses - (Commissioned work cost + Unused material and article costs + Auxiliary service cost))/ Revenue water volume (unit: yen/m ³)	5413	(1) Operating Expenses [(a)~ (j)] (1,000 yen)
				5424	(2) Non-operating Expenses [(a)~ (e)] (1,000 yen)
				5418	(e) Expense on Trusted Construction (1,000 yen)
				3703	Cost of Materials, etc. sold among Previous "Others" (1,000 yen)
				3704	Incidental Expenses (1,000 yen)
				5022	Annual Water Supply Volume/ Breakdown/ Billed Water Consumption (1,000 m ³)
				5027	Annual Bulk Water Supply Volume/ Breakdown/ Billed Water Consumption (1,000 m ³)
				5032	Annual Water supply volume to another water supplier/ Breakdown/ Billed Water Consumption (1,000 m ³)
				0117	Tariff for Households/ monthly/ Basic Charge (Yen)
				0134	Tariff for Households/ monthly/ Bill for Consumption of 10 m ³
3016	Charge for one month per 10 m ³ for domestic	This indicator represents charges that the standard household pays for using water, and is one of indices showing the economical convenience of consumers. It is inevitable that different water utilities offer different water rates because they have different water resources, locations, waterworks facilities construction timing, operating scales, and labor and facilities maintenance costs. However, a large disparity in regions should be avoidable because water is indispensable to daily life. Water utilities should compare their water rates with the average to take measures for eliminating the disparity.	Charge for one month per 10 m ³ for domestic = Monthly minimum charge (13-mm diameter) + Meter rate per 10 cubic meters (unit: yen)		

3017	Charge for one month per 20 m ³ for domestic	This indicator represents charges that the standard household pays for using water, and is one of indices showing the economical convenience of consumers. It is inevitable that different water utilities offer different water rates because they have different water resources, locations, waterworks facilities construction timing, operating scales, and labor and facilities maintenance costs. However, a large disparity in regions should be avoidable because water is indispensable to daily life. Water utilities should compare their water rates with the average to take measures for eliminating the disparity.	Charge for one month per 20 m ³ for domestic = Monthly minimum charge (13-mm diameter) + Meter rate per 20 cubic meters (unit: yen)	0117	Tariff for Households/ monthly/ Basic Charge (Yen)
				0133	Tariff for Households/ monthly/ Bill for Consumption of 20 m ³
3018	Revenue water ratio	This indicator represents the ratio of revenue water to distribution input (supply volume) in a year, and allows water utilities to check whether the operation of facilities yields revenue.	Revenue water ratio = (Revenue water volume/ Supply volume) × 100 (unit: %)	5022	Annual Water Supply Volume/ Breakdown/ Billed Water Consumption (1,000 m ³)
				5027	Annual Bulk Water Supply Volume/ Breakdown/ Billed Water Consumption (1,000 m ³)
				5032	Annual Water supply volume to another water supplier/ Breakdown/ Billed Water Consumption (1,000 m ³)
				5020	Annual Water Supply Volume/ Annual Water Supply Volume (1,000 m ³)
3019	Rate of facility utilization	This indicator shows the ratio of the average daily supply to the daily capacity, and allows water utilities to make a comprehensive judgment regarding the cost effectiveness of waterworks facilities. The larger the value, the higher the efficiency. The indicator is also given by multiplying the maximum operation rate and the load factor. If the indicator value is small because the maximum operation rate is low, not the load factor, it tells that investments are too much and that part of facilities is idle.	Rate of facility utilization = (Average daily supply/ Daily capacity) × 100 (unit: %)	5106	Water Supply Volume per Day/ Daily Average Water Supply Volume (m ³)
				5118	Capacity of Facilities (m ³ / day)
3020	Maximum rate of operation	This indicator should define the ratio of the longest to the planned in the daily operating time of facilities, but it is difficult to find them. As a result, it represents the ratio of the maximum daily supply to the daily capacity, and is one of indices showing the efficiency of waterworks facilities.	Maximum rate of operation = (Maximum daily supply/ Daily capacity) × 100 (unit: %)	5103	Water Supply Volume per Day/ Daily Maximum Water Supply Volume (m ³)
				5118	Capacity of Facilities (m ³ / day)
3021	Average rate of loading	This indicator is one of indices showing the efficiency of waterworks facilities. The larger the value, the higher the efficiency. In the water industry, the demand varies season by season and the facilities are designed to meet	Average rate of loading = (Average daily supply/ Maximum daily supply) × 100 (unit: %)	5106	Water Supply Volume per Day/ Daily Average Water Supply Volume (m ³)

		a demand peak. As a result, the larger the demand variation, the lower the efficiency and load factor.		5103	Water Supply Volume per Day/ Daily Maximum Water Supply Volume (m3)
3022	Current ratio	This indicator represents the ratio of the current assets to the current liabilities, that is, the capability of paying short-term obligations. The indicator value should be over 100 percent, otherwise a bad debt occurs.	Current ratio = (Current assets/ Current liabilities) × 100 (unit: %)	5510	2 / Current Assets [(1)~ (3)] (1,000 yen)
				5517	6 / Current Liabilities [(1)~ (2)] (1,000 yen)
3023	Ratio of net worth to total capital	This indicator represents the ratio of the owned capital to the total capital (liabilities plus capital), and is one of indices showing the soundness of finance. Water utilities should increase the indicator value to make their operation stable.	Ratio of net worth to total capital = ((Owned capital + Surplus)/ Total of liabilities and capital) × 100 (unit: %)	5522	(1) Equity Capital (1,000 yen)
				5526	9 / Accumulated Profit [(1)~ (2)] (1,000 yen)
				5538	1 1 / Liabilities/ Total Capital [7 + 1 0] (1,000 yen)
3024	Ratio of fixed assets to equity capital	This indicator shows how much owned capital is invested in the fixed assets. If the value is within 100 percent, it means that investments in the fixed assets are within the owned capital. If the value exceeds 100 percent, it means that loans are given to capital investment, which causes problems, such as the payment of the loans and interests.	Ratio of fixed assets to equity capital = (Fixed assets/ (Owned capital + Surplus)) × 100 (unit: %)	5501	1 / Fixed Assets [(1)~ (3)] (1,000 yen)
				5522	(1) Equity Capital (1,000 yen)
				5526	9 / Accumulated Profit [(1)~ (2)] (1,000 yen)
3025	Ratio of principal redemption cost on revenue bond to depreciation cost	This indicator shows the balance between invested capital recovery and reinvestment. If the indicator value exceed 100 percent, the soundness of investment deteriorates because the reinvestment relies on external funds like corporate bonds.	Ratio of principal redemption cost on revenue bond to depreciation cost = (Redemption principal/ Depreciation cost) × 100 (unit: %)	5617	2 / Capital Expenditure (3) Redemption of Public Corporation Bonds (1,000 yen)
				5421	(h) Depreciation Expense (1,000 yen)
3026	Turnover of fixed assets	This indicator represents the ratio of the operating income to the fixed assets, that is, how many times larger than the fixed assets the operating income is in a given period of time. The fixed assets turnover is very important because drinking water supply services relate closely to facilities. If the indicator value is large, the facilities run effectively, but if small, excess investments may occur.	Turnover of fixed assets = (Operating income - Commissioned work income)/ ((Initial fixed assets + Final fixed assets)/2) (unit: rotations)	5402	(1) Operating Income [(a)~ (c)] (1,000 yen)
				5418	(e) Expense on Trusted Construction (1,000 yen)
				5501	1 / Fixed Assets [(1)~ (3)] (1,000 yen)
				5501	1 / Fixed Assets [(1)~ (3)] (1,000 yen)
3027	Efficiency of fixed assets utilization	This indicator represents the ratio of the annual water supply volume to the tangible fixed assets. The larger the value, the more efficient the facilities. If the indicator	Efficiency of fixed assets utilization = (Supply volume/ Tangible fixed assets) × 10,000 (unit: m3/10,000	5020	Annual Water Supply Volume/ Annual Water Supply Volume (1,000 m3)

		value is low, water utilities should examine idle and unproductive assets.	yen)	5502	(1) Tangible Fixed Assets [(a)~(e)] (1,000 yen)
3101	Number of employees' qualifications	Offering drinking water supply services need statutory licenses. Water utilities can commission third parties to conduct any work, but should have qualified staff members. The qualification is classified into statutory and private licenses, but this indicator employs only the statutory. It does not include qualifications obtained as a personal interest.	Number of employees' qualifications = Number of statutory qualifications/ Total number of staff members (unit: No./person)	3505	Number of Qualified person of Technical administrator of waterworks/ Employee (Capita)
				3509	Number of Qualified person of Inspector for water facilities construction/ Employee (Capita)
				0326	Number of Personnel/ Sub/ Total (Capita)
3105	Technical employee's ratio	The inheritance of technology is necessary and important, but in current times, the number of engineers decreases. As the indicator value is reducing, it is more difficult for water utilities to maintain the facilities by themselves.	Technical employee's ratio = (Number of engineers/ Total number of staff members) × 100 (unit: %)	0321	Number of Personnel/ Engineering Staff/ Total (Capita)
				0326	Number of Personnel/ Sub/ Total (Capita)
3109	Transmission input per employee	This indicator is one of indices showing the efficiency of whole drinking water supply services.	Transmission input per employee = Annual distribution input/ Total number of staff members (unit: m3/person)	5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
				0326	Number of Personnel/ Sub/ Total (Capita)
3110	Number of meters per employee	This indicator is one of indices showing the efficiency of whole drinking water supply services.	Number of meters per employee = Number of water meters/ Total number of staff members (unit: No./person)	5215	Number of installed meter
				0326	Number of Personnel/ Sub/ Total (Capita)
4001	Electric power consumption per 1 m3 transmission input	Since it is important to keep power even in the event of an accident, duplex power lines may be necessary without compromising the efficiency in view of environmental protection and risk dispersion. The power consumption varies particularly depending on the geographical features of distribution systems.	Electric power consumption per 1 m3 transmission input = Total power consumption/ Annual transmission input (unit: kWh/m3)	6119	Electric Power Consumption [†] (kWh)
				5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
4002	Energy consumption per 1 m3 transmission input	Energy saving is encouraged to preserve the global environment. This indicator (MJ/m3) can be used to	Energy consumption per 1 m3 transmission input = Total energy		

	m3 transmission input	select measures effective in reducing environmental loads, for example, when water utilities find a target value for energy reduction.	consumption/ Annual transmission input (unit: MJ/m3)	6119 4401~4423 5018 5011	Electric Power Consumption [†] (kWh) Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3) Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
4003	Renewable energy use ratio	This indicator represents the percentage of recyclable energy used by a water utility, and is one of indices showing the reduction of environmental loads and environmental preservation. It is desired to improve the efficiency of energy utilization and to decrease environmental loads by using unused and recyclable energy.	Renewable energy use ratio = (Recyclable power consumption/ Total power consumption) × 100 (unit: %)	4501	Renewable Energy Facilities/ Electric Power Consumption/ Hydroelectric Power Generation (kWh)
				4502	Renewable Energy Facilities/ Electric Power Consumption/ Solar Power Generation (kWh)
				4503	Renewable Energy Facilities/ Electric Power Consumption/ Wind Power Generation (kWh)
				4504	Renewable Energy Facilities/ Electric Power Consumption/ Other Power Generation (kWh)
				6119	Electric Power Consumption [†] (kWh)
4004	Recycling ratio of generated sludge from purification plants	This indicator represents the effective use of sludge deposited during purification, and is one of indices showing the extent to which water utilities conserve the environment. Setting up a target value for this indicator can embody environmental activities (including environmental management systems).	Recycling ratio of generated sludge from purification plants = (Amount of used sludge/ Amount of deposited sludge) × 100 (unit: %)	0833	Operation Condition/ Disposition Method of Soil Produced in Water Purification/ Effective Utilization (%)
4005	Recycling ratio of construction by-product	This indicator represents the effective use of by-products generated during construction, and is one of indices showing the extent to which water utilities conserve the environment. Setting up a target value for this indicator can embody environmental activities (including environmental management systems).	Recycling ratio of construction by-product = (Amount of recycled by-products/ Amount of generated by-products) × 100 (unit: %)	4301~4307	
				4315~4321	
4006	Emission of CO2 per 1 m3 transmission input	This indicator is one element of environmental measures, which water utilities take to reduce the amount of greenhouse gases.	Emission of CO2 per 1 m3 transmission input = (Carbon dioxide emission/ Annual transmission input) × 106 (unit: g CO2/m3)		
				6120	Contracted Electric Power Company (1)
				6119	Electric Power Consumption [†] (kWh)

				4401～4423	
				5018	Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m3)
				5011	Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m3)
4101	Underground water ratio	Water resources have surface and underground water, and the smaller the scale of water utilities, the larger the ratio of underground water. This is because the underground water is low in cost and stable, that is, the utilization value is high. However, water utilities should take care of the allowable volume of water because excess pumping may cause a land subsidence.	Underground water ratio = (Pumping discharge/ Water resource volume) × 100 (unit: %)	5006	Annual Water Abstraction Volume/ Ground Water/ Shallow Well Water (1,000 m3)
				5007	Annual Water Abstraction Volume/ Ground Water/ Deep Well Water (1,000 m3)
				5010	Annual Water Abstraction Volume/ Sub/ Total (1,000 m3)
5009	Outsourced purification plant ratio	Conventionally, no engineer was stationed in commissioned purification plants, but this indicator is applied only to third parties based on the law. This is because the conventional commission does not specify the scope strictly. This indicator employs the purification capacity rather than the number of purification plants because the former can clearly show the extent to which the plants are commissioned.	Outsourced purification plant ratio = (Commissioned purification capacity/ Total purification capacity) (unit: %)	3410	Capacity of Water Purification Plants Entrusted to Third Party (m3/ day)
				5118	Capacity of Facilities (m3/ day)
5101	Number of purification plant accident	Many accidents occur in purification plants, but typically, the duplex system and backup function of facilities avoid a water purification or transmission failure because it has a serious impact.	Number of purification plant accident = Number of accidents for ten years/ Number of purification plants (unit: No./plant/ 10 years)	3813	Suspension time of water purification plants (times/ year)
				0545	Water Purification Plant/ Number of Water Purification Plant/ Slow Sand Filtration System
				0546	Water Purification Plant/ Number of Water Purification Plant/ Rapid Sand Filtration System
				0553	Water Purification Plant/ Number of Water Purification Plant/ Membrane Filtration System
5102	Ratio of ductile iron and steel mains	This indicator focuses on the material strength of conveyance, transmission, and distribution pipes, that is, the maintainability.	Ratio of ductile iron and steel mains = ((Length of ductile cast iron pipes + Length of steel pipes)/ Total pipeline length) × 100 (unit: %)	6802	Length of Raw Water Conveyance pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)
				6803	Length of Raw Water Conveyance pipes/ Ductile Iron pipes/ Except Previous item (m)

6814	Length of Water Transmission pipes Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)
6815	Length of Water Transmission pipes Ductile Iron pipes/ Except Previous item (m)
6826	Length of Water Distribution pipes/ Distributing Main pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)
6827	Length of Water Distribution pipes/ Distributing Main pipes/ Ductile Iron pipes/ Except Previous item (m)
6838	Length of Water Distribution pipes/ Distributing Branch pipes/ Ductile Iron pipes (Connected with Earthquake-resistant Joint) (m)
6839	Length of Water Distribution pipes/ Distributing Branch pipes/ Ductile Iron pipes/ Except Previous item (m)
6866	Length of Raw Water Conveyance pipes/ Ductile Iron pipes (Connected with K-type Mechanical Joint and Installed on the Stable Ground) (m)
6867	Length of Water Transmission pipes Ductile Iron pipes (Connected with K-type Mechanical Joint and Installed on the Stable Ground) (m)
6868	Length of Water Distribution pipes/ Distributing Main pipes/ Ductile Iron pipes (Connected with K-type Mechanical Joint and Installed on the Stable Ground) (m)
6869	Length of Water Distribution pipes/ Distributing Branch pipes/ Ductile Iron pipes (Connected with K-type Mechanical Joint and Installed on the Stable Ground) (m)
6804	Length of Raw Water Conveyance pipes/ Steel pipes (m)
6816	Length of Water Transmission pipes Steel pipes (m)
6828	Length of Water Distribution pipes/ Distributing Main pipes/ Steel pipes (m)

				6840	Length of Water Distribution pipes/ Distributing Branch pipes/ Steel pipes (m)
				0701	Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total (m)
				0706	Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)
				0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
5103	Number of pipeline failures	This indicator represents the annual sum of accidents in conveyance, transmission, and distribution pipes per pipeline length of 100 km, that is, the soundness of the pipelines There are various accidents; their scale and impact are different. Since this indicator evaluates failed pipelines from a facility control point of view, it ignores the scale of accidents. The influence of accidents varies depending on environmental conditions and measures, and any accident has a possibility of causing serious damage.	Number of pipeline failures = (Number of pipeline failures/ Total pipeline length) × 100 (unit: No./100 km)	3814 0701 0706 0711	Number of pipeline accidents (times/ year) Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m) Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
5106	Number of service pipe failures	This indicator shows the soundness of service pipes from branch points to water meters. As a rule, consumers are responsible for maintaining service equipment, but water utilities should support it actively to improve drinking water supply services.	Number of service pipe failures = (Number of service pipe failures/ Total number of users) × 1,000 (unit: No./1,000 No.)	3910 5214 5342	Number of water supply pipe accidents (times) Tariff structure by customer use/ Number of Household/ Total Tariff structure by meter size/ Number of Household/ Total
5107	Leakage rate	Knowing the volume of water is basic to maintenance, so water utilities should make correct measurements. Since it is impossible to measure the volume of leaked water directly, water utilities are obliged to do estimations. It is recommended that water utilities use a logical analysis as shown in the section "4.3 Structure of classified water quantity."	Leakage rate = (Annual leakage/ Annual transmission input) × 100 (unit: %)	3911 5018 5011	Annual Water leakage volume (m ³ / year) Annual Water Purified Volume/ Annual Water Purified Volume/ Total (1,000 m ³) Annual Water Abstraction Volume/ Purified Water Receiving (1,000 m ³)
5108	Leakage volume per contracted service connection	Knowing the volume of water is basic to maintenance, so water utilities should make correct measurements. Since it is impossible to measure the volume of leaked water directly, water utilities are obliged to do estimations. It is recommended that water utilities use a logical analysis as shown in the section "4.3 Structure of classified water quantity."	Leakage volume per contracted service connection = Annual leakage/ Total number of users (unit: m ³ /connection)	3911 5214	Annual Water leakage volume (m ³ / year) Tariff structure by customer use/ Number of Household/ Total

		quantity.”		5342	Tariff structure by meter size/ Number of Household/ Total
5109	Hour of water interruption or water turbidity	A drought causes a water cut, but it is not sudden. This indicator includes only accidental water cuts. If private plumbing work interrupts water supply, it is excluded because of private responsibilities.	Hour of water interruption or water turbidity = (Water cut and turbidity time × Suffered service population)/ Service population (unit: hour)	9201	
				9202	
				0206	Population/ Water Supply Population (Capita)
5112	Valve density	This indicator shows the flexibility of water distribution and the maintainability of pipelines. Water utilities should deploy the valves in appropriate places while considering the configuration and geographical features of pipeline facilities in order to average the dynamic water pressure, to use water rationally, and to maintain the pipelines properly. Moreover, water utilities should install the valves to minimize the area where an emergency water cut occurs.	Valve density = Number of valves/ Total pipeline length (unit: No./km)	0747	Number of Installed Valve
				0701	Length of Raw Water Conveyance pipes/ Classified by Diameter/ Length of Raw Water Conveyance pipes/ Total (m)
				0706	Length of Water Transmission pipes Classified by Diameter/ Length of Water Transmission pipes/ Total (m)
				0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)
5114	Hydrant density	This indicator shows the pipeline facility's capabilities of firefighting and risk management as a lifesaving line. The waterworks play the role of supplying water for firefighting, so the hydrant supplies water when a fire occurs.	Hydrant density = Total number of hydrants/ Distribution pipe length (Unit: No./km)	0743	Number of Fire Hydrant 地上(基)
				0744	Number of Fire Hydrant 地下(基)
				0745	Number of Fire Hydrant/ Others (基)
				0711	Length of Water Distribution pipes Classified by Diameter/ Length of Water Distribution pipes/ Total (m)