

水質項目		計	区分										
一般細菌			0	～10	～20	～30	～40	～50	～60	～70	～80	～100	101～
	全体	9,359	8,886	455	13	2	2	1	0	0	0	0	0
	表流水	2,132	2,008	118	3	1	2	0	0	0	0	0	0
	ダム湖沼	324	309	15	0	0	0	0	0	0	0	0	0
	地下水	4,734	4,496	227	10	1	0	0	0	0	0	0	0
	その他	2,169	2,073	95	0	0	0	1	0	0	0	0	0
大腸菌(定性)			陰性	陽性									
	全体	9,359	9,356	3									
	表流水	2,132	2,132	0									
	ダム湖沼	324	324	0									
	地下水	4,734	4,733	1									
	その他	2,169	2,167	2									
カドミウム及びその化合物			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	8,393	8,387	1	5	0	0	0	0	0	0	0	0
	表流水	1,932	1,932	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	290	290	0	0	0	0	0	0	0	0	0	0
	地下水	4,210	4,206	0	4	0	0	0	0	0	0	0	0
	その他	1,961	1,959	1	1	0	0	0	0	0	0	0	0
水銀及びその化合物			～0.00005	～0.00010	～0.00015	～0.00020	～0.00025	～0.00030	～0.00035	～0.00040	～0.00045	～0.00050	0.00051～
	全体	8,287	8,272	9	0	0	0	0	0	0	0	6	0
	表流水	1,889	1,885	1	0	0	0	0	0	0	0	3	0
	ダム湖沼	287	287	0	0	0	0	0	0	0	0	0	0
	地下水	4,180	4,171	8	0	0	0	0	0	0	0	1	0
	その他	1,931	1,929	0	0	0	0	0	0	0	0	2	0
セレン及びその化合物			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	8,372	8,359	11	1	0	0	0	0	0	0	1	0
	表流水	1,932	1,930	2	0	0	0	0	0	0	0	0	0
	ダム湖沼	290	290	0	0	0	0	0	0	0	0	0	0
	地下水	4,205	4,196	9	0	0	0	0	0	0	0	0	0
	その他	1,945	1,943	0	1	0	0	0	0	0	0	1	0
鉛及びその化合物			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	8,589	8,361	145	51	17	7	5	1	1	0	1	0
	表流水	1,985	1,963	17	5	0	0	0	0	0	0	0	0
	ダム湖沼	310	306	3	1	0	0	0	0	0	0	0	0
	地下水	4,297	4,136	102	34	13	6	4	1	1	0	0	0
	その他	1,997	1,956	23	11	4	1	1	0	0	0	1	0
ヒ素及びその化合物			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	8,489	7,700	402	178	94	52	23	20	11	7	2	0
	表流水	1,940	1,842	53	27	8	4	3	2	1	0	0	0
	ダム湖沼	290	285	1	3	0	1	0	0	0	0	0	0
	地下水	4,282	3,731	282	111	75	39	18	13	6	5	2	0
	その他	1,977	1,842	66	37	11	8	2	5	4	2	0	0
六価クロム化合物			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	8,562	8,515	32	10	1	2	0	0	0	0	2	0
	表流水	1,973	1,961	8	4	0	0	0	0	0	0	0	0
	ダム湖沼	305	305	0	0	0	0	0	0	0	0	0	0
	地下水	4,279	4,252	19	5	1	1	0	0	0	0	1	0
	その他	2,005	1,997	5	1	0	1	0	0	0	0	1	0
亜硝酸態窒素			～0.004	～0.008	～0.012	～0.016	～0.020	～0.024	～0.028	～0.032	～0.036	～0.040	0.041～
	全体	8,615	8,592	21	2	0	0	0	0	0	0	0	0
	表流水	2,000	1,997	3	0	0	0	0	0	0	0	0	0
	ダム湖沼	302	302	0	0	0	0	0	0	0	0	0	0
	地下水	4,320	4,306	12	2	0	0	0	0	0	0	0	0
	その他	1,993	1,987	6	0	0	0	0	0	0	0	0	0
シアン化物イオン及び塩化シアン			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	9,345	9,344	1	0	0	0	0	0	0	0	0	0
	表流水	2,131	2,131	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	324	324	0	0	0	0	0	0	0	0	0	0
	地下水	4,721	4,720	1	0	0	0	0	0	0	0	0	0
	その他	2,169	2,169	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
硝酸態窒素及び亜硝酸態窒素			～0.50	～1.00	～2.00	～3.00	～4.00	～5.00	～6.00	～7.00	～8.00	～10.00	10.01～
	全体	8,813	4,684	2,002	1,335	419	169	85	72	29	14	4	0
	表流水	1,991	1,386	441	142	20	1	0	1	0	0	0	0
	ダム湖沼	304	246	47	7	3	0	0	0	1	0	0	0
	地下水	4,485	1,852	1,116	897	309	136	74	65	20	12	4	0
	その他	2,033	1,200	398	289	87	32	11	6	8	2	0	0
フッ素及びその化合物			～0.08	～0.16	～0.24	～0.32	～0.40	～0.48	～0.56	～0.64	～0.72	～0.80	0.81～
	全体	8,608	6,631	1,506	263	97	47	31	12	11	5	5	0
	表流水	1,971	1,718	195	25	15	8	5	1	1	2	1	0
	ダム湖沼	298	241	45	8	1	2	1	0	0	0	0	0
	地下水	4,340	3,102	892	195	70	34	24	9	8	2	4	0
	その他	1,999	1,570	374	35	11	3	1	2	2	1	0	0
ホウ素及びその化合物			～0.1	～0.2	～0.3	～0.4	～0.5	～0.6	～0.7	～0.8	～0.9	～1.0	1.1～
	全体	8,422	8,257	78	43	13	16	11	1	2	1	0	0
	表流水	1,932	1,915	9	5	0	1	1	0	1	0	0	0
	ダム湖沼	289	286	1	1	0	1	0	0	0	0	0	0
	地下水	4,233	4,134	52	20	9	11	6	0	1	0	0	0
	その他	1,968	1,922	16	17	4	3	4	1	0	1	0	0
四塩化炭素			～0.0002	～0.0004	～0.0006	～0.0008	～0.0010	～0.0012	～0.0014	～0.0016	～0.0018	～0.0020	0.0021～
	全体	8,365	8,351	8	0	0	0	0	0	0	0	6	0
	表流水	1,929	1,925	1	0	0	0	0	0	0	0	3	0
	ダム湖沼	286	286	0	0	0	0	0	0	0	0	0	0
	地下水	4,206	4,197	7	0	0	0	0	0	0	0	2	0
	その他	1,944	1,943	0	0	0	0	0	0	0	0	1	0
1,4－ジオキサン			～0.005	～0.010	～0.015	～0.020	～0.025	～0.030	～0.035	～0.040	～0.045	～0.050	0.051～
	全体	8,347	8,343	2	0	0	1	0	0	0	0	1	0
	表流水	1,920	1,919	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	286	286	0	0	0	0	0	0	0	0	0	0
	地下水	4,201	4,200	0	0	0	1	0	0	0	0	0	0
	その他	1,940	1,938	1	0	0	0	0	0	0	0	1	0
シス－1,2－ジクロロエチレン及びトランス－1,2－ジクロロエチレン			～0.004	～0.008	～0.012	～0.016	～0.020	～0.024	～0.028	～0.032	～0.036	～0.040	0.041～
	全体	8,362	8,354	6	1	0	0	0	0	0	0	1	0
	表流水	1,928	1,928	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	285	285	0	0	0	0	0	0	0	0	0	0
	地下水	4,204	4,197	6	1	0	0	0	0	0	0	0	0
	その他	1,945	1,944	0	0	0	0	0	0	0	0	1	0
ジクロロメタン			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	8,364	8,355	7	2	0	0	0	0	0	0	0	0
	表流水	1,929	1,929	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	286	286	0	0	0	0	0	0	0	0	0	0
	地下水	4,205	4,197	6	2	0	0	0	0	0	0	0	0
	その他	1,944	1,943	1	0	0	0	0	0	0	0	0	0
テトラクロロエチレン			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	8,363	8,348	11	2	1	1	0	0	0	0	0	0
	表流水	1,929	1,928	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	286	286	0	0	0	0	0	0	0	0	0	0
	地下水	4,204	4,191	10	1	1	1	0	0	0	0	0	0
	その他	1,944	1,943	0	1	0	0	0	0	0	0	0	0
トリクロロエチレン			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	8,369	8,354	11	1	3	0	0	0	0	0	0	0
	表流水	1,928	1,926	1	0	1	0	0	0	0	0	0	0
	ダム湖沼	286	286	0	0	0	0	0	0	0	0	0	0
	地下水	4,209	4,196	10	1	2	0	0	0	0	0	0	0
	その他	1,946	1,946	0	0	0	0	0	0	0	0	0	0
ベンゼン			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	8,363	8,354	6	0	0	2	0	0	0	0	1	0
	表流水	1,928	1,926	1	0	0	0	0	0	0	0	1	0
	ダム湖沼	286	286	0	0	0	0	0	0	0	0	0	0
	地下水	4,205	4,198	5	0	0	2	0	0	0	0	0	0
	その他	1,944	1,944	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
塩素酸			～0.06	～0.12	～0.18	～0.24	～0.30	～0.36	～0.42	～0.48	～0.54	～0.60	0.61～
	全体	9,350	6,467	1,939	600	207	83	33	9	2	2	2	6
	表流水	2,131	1,170	597	236	78	37	7	0	1	0	0	5
	ダム湖沼	324	132	108	49	22	8	3	1	0	0	1	0
	地下水	4,726	3,508	822	246	86	35	18	8	1	1	1	0
	その他	2,169	1,657	412	69	21	3	5	0	0	1	0	1
クロロ酢酸			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	9,350	9,342	3	0	0	0	0	0	0	0	5	0
	表流水	2,131	2,127	3	0	0	0	0	0	0	0	1	0
	ダム湖沼	324	324	0	0	0	0	0	0	0	0	0	0
	地下水	4,726	4,723	0	0	0	0	0	0	0	0	3	0
	その他	2,169	2,168	0	0	0	0	0	0	0	0	1	0
クロロホルム			～0.006	～0.012	～0.018	～0.024	～0.030	～0.036	～0.042	～0.048	～0.056	～0.060	0.061～
	全体	9,350	6,929	1,548	621	171	63	13	4	1	0	0	0
	表流水	2,131	1,010	668	306	102	40	4	1	0	0	0	0
	ダム湖沼	324	102	112	57	31	14	7	1	0	0	0	0
	地下水	4,726	4,351	272	75	18	7	2	0	1	0	0	0
	その他	2,169	1,466	496	183	20	2	0	2	0	0	0	0
ジクロロ酢酸			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	9,350	8,095	871	262	90	23	5	4	0	0	0	0
	表流水	2,131	1,414	471	162	64	15	4	1	0	0	0	0
	ダム湖沼	324	205	65	28	17	5	1	3	0	0	0	0
	地下水	4,726	4,568	129	24	4	1	0	0	0	0	0	0
	その他	2,169	1,908	206	48	5	2	0	0	0	0	0	0
ジブロモクロロメタン			～0.01	～0.02	～0.03	～0.04	～0.05	～0.06	～0.07	～0.08	～0.09	～0.10	0.11～
	全体	9,350	9,212	108	23	3	1	2	0	1	0	0	0
	表流水	2,131	2,090	34	4	2	0	0	0	1	0	0	0
	ダム湖沼	324	309	13	2	0	0	0	0	0	0	0	0
	地下水	4,726	4,666	39	17	1	1	2	0	0	0	0	0
	その他	2,169	2,147	22	0	0	0	0	0	0	0	0	0
臭素酸			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	9,350	9,248	78	16	5	2	0	0	1	0	0	0
	表流水	2,131	2,106	19	3	2	1	0	0	0	0	0	0
	ダム湖沼	324	321	3	0	0	0	0	0	0	0	0	0
	地下水	4,726	4,698	19	4	3	1	0	0	1	0	0	0
	その他	2,169	2,123	37	9	0	0	0	0	0	0	0	0
総トリハロメタン			～0.010	～0.020	～0.030	～0.040	～0.050	～0.060	～0.070	～0.080	～0.090	～0.100	0.101～
	全体	9,349	6,236	1,813	878	299	91	23	5	4	0	0	0
	表流水	2,131	831	748	392	117	31	9	1	2	0	0	0
	ダム湖沼	324	54	126	72	34	31	5	2	0	0	0	0
	地下水	4,725	4,066	457	139	47	10	3	2	1	0	0	0
	その他	2,169	1,285	482	275	101	19	6	0	1	0	0	0
トリクロロ酢酸			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	9,349	7,106	1,127	637	271	117	50	32	6	1	2	0
	表流水	2,131	1,038	491	297	166	79	34	21	4	1	0	0
	ダム湖沼	324	130	81	48	30	18	7	8	2	0	0	0
	地下水	4,725	4,394	204	81	25	10	6	3	0	0	2	0
	その他	2,169	1,544	351	211	50	10	3	0	0	0	0	0
ブロモジクロロメタン			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	9,349	6,667	1,582	728	272	63	26	8	2	1	0	0
	表流水	2,131	1,086	622	282	95	30	10	3	2	1	0	0
	ダム湖沼	324	71	119	72	37	12	10	3	0	0	0	0
	地下水	4,725	4,141	408	135	31	8	2	0	0	0	0	0
	その他	2,169	1,369	433	239	109	13	4	2	0	0	0	0
ブロモホルム			～0.009	～0.018	～0.027	～0.036	～0.045	～0.054	～0.063	～0.072	～0.081	～0.090	0.091～
	全体	9,349	9,270	70	8	0	0	1	0	0	0	0	0
	表流水	2,131	2,108	21	2	0	0	0	0	0	0	0	0
	ダム湖沼	324	315	9	0	0	0	0	0	0	0	0	0
	地下水	4,725	4,693	27	4	0	0	1	0	0	0	0	0
	その他	2,169	2,154	13	2	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
ホルムアルデヒド			～0.008	～0.016	～0.024	～0.032	～0.040	～0.048	～0.056	～0.064	～0.072	～0.080	0.081～
	全体	9,349	9,333	16	0	0	0	0	0	0	0	0	0
	表流水	2,131	2,130	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	324	324	0	0	0	0	0	0	0	0	0	0
	地下水	4,725	4,712	13	0	0	0	0	0	0	0	0	0
	その他	2,169	2,167	2	0	0	0	0	0	0	0	0	0
亜鉛及びその化合物			～0.02	～0.04	～0.06	～0.08	～0.10	～0.20	～0.40	～0.60	～0.80	～1.00	1.01～
	全体	8,517	8,074	129	89	19	181	15	9	1	0	0	0
	表流水	1,960	1,874	25	12	3	44	1	0	1	0	0	0
	ダム湖沼	301	292	2	3	1	3	0	0	0	0	0	0
	地下水	4,266	3,974	73	67	13	118	12	9	0	0	0	0
	その他	1,990	1,934	29	7	2	16	2	0	0	0	0	0
アルミニウム及びその化合物			～0.02	～0.04	～0.06	～0.08	～0.10	～0.12	～0.14	～0.16	～0.18	～0.20	0.21～
	全体	8,677	7,322	968	254	76	36	10	4	4	1	1	1
	表流水	2,018	1,512	336	103	37	18	6	3	2	0	1	0
	ダム湖沼	314	216	62	27	7	1	0	0	0	1	0	0
	地下水	4,323	3,994	223	65	20	15	3	0	2	0	0	1
	その他	2,022	1,600	347	59	12	2	1	1	0	0	0	0
鉄及びその化合物			～0.03	～0.06	～0.09	～0.12	～0.15	～0.18	～0.21	～0.24	～0.27	～0.30	0.31～
	全体	8,624	8,408	144	46	10	7	5	2	0	0	2	0
	表流水	2,003	1,941	43	10	5	2	1	0	0	0	1	0
	ダム湖沼	309	300	5	3	1	0	0	0	0	0	0	0
	地下水	4,306	4,207	66	24	1	4	2	1	0	0	1	0
	その他	2,006	1,960	30	9	3	1	2	1	0	0	0	0
銅及びその化合物			～0.02	～0.04	～0.06	～0.08	～0.10	～0.20	～0.40	～0.60	～0.80	～1.00	1.01～
	全体	8,522	8,009	187	75	29	195	19	4	4	0	0	0
	表流水	1,963	1,888	16	2	3	53	1	0	0	0	0	0
	ダム湖沼	305	295	4	2	1	3	0	0	0	0	0	0
	地下水	4,264	3,892	143	62	21	124	14	4	4	0	0	0
	その他	1,990	1,934	24	9	4	15	4	0	0	0	0	0
ナトリウム及びその化合物			～5.0	～10.0	～20.0	～40.0	～60.0	～80.0	～100.0	～120.0	～150.0	～200.0	200.1～
	全体	8,463	1,915	3,691	2,233	535	61	21	4	2	1	0	0
	表流水	1,946	681	818	388	55	4	0	0	0	0	0	0
	ダム湖沼	296	39	137	81	37	2	0	0	0	0	0	0
	地下水	4,247	649	1,934	1,271	321	48	18	3	2	1	0	0
	その他	1,974	546	802	493	122	7	3	1	0	0	0	0
マンガン及びその化合物			～0.005	～0.010	～0.015	～0.020	～0.025	～0.030	～0.035	～0.040	～0.045	～0.050	0.051～
	全体	8,528	8,437	63	14	6	0	0	0	0	2	5	1
	表流水	1,969	1,955	9	2	1	0	0	0	0	0	2	0
	ダム湖沼	304	298	5	0	0	0	0	0	0	1	0	0
	地下水	4,261	4,199	46	10	2	0	0	0	0	1	2	1
	その他	1,994	1,985	3	2	3	0	0	0	0	0	1	0
塩化物イオン			～5.0	～10.0	～20.0	～40.0	～60.0	～80.0	～100.0	～120.0	～150.0	～200.0	200.1～
	全体	9,358	2,966	3,183	2,245	763	149	33	10	5	4	0	0
	表流水	2,132	791	635	521	174	11	0	0	0	0	0	0
	ダム湖沼	324	31	82	143	49	15	3	0	0	1	0	0
	地下水	4,733	1,394	1,787	1,129	319	68	21	8	4	3	0	0
	その他	2,169	750	679	452	221	55	9	2	1	0	0	0
カルシウム、マグネシウム等(硬度)			～10	～20	～30	～50	～80	～100	～150	～200	～250	～300	301～
	全体	8,823	378	1,241	1,523	2,761	2,035	514	314	45	9	2	1
	表流水	1,979	224	511	425	493	249	50	26	1	0	0	0
	ダム湖沼	302	19	39	74	103	44	15	6	1	0	0	1
	地下水	4,474	66	341	614	1,512	1,340	339	223	32	5	2	0
	その他	2,068	69	350	410	653	402	110	59	11	4	0	0
蒸発残留物			～30	～50	～100	～150	～200	～250	～300	～350	～400	～500	501～
	全体	8,969	133	965	3,941	2,341	1,111	335	89	28	20	6	0
	表流水	1,994	82	466	1,051	296	77	15	6	1	0	0	0
	ダム湖沼	308	1	30	189	46	28	11	2	0	1	0	0
	地下水	4,563	16	228	1,691	1,552	745	218	70	25	14	4	0
	その他	2,104	34	241	1,010	447	261	91	11	2	5	2	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
陰イオン界面活性剤			～0.02	～0.04	～0.06	～0.08	～0.10	～0.12	～0.14	～0.16	～0.18	～0.20	0.21～
	全体	8,265	8,258	7	0	0	0	0	0	0	0	0	0
	表流水	1,878	1,877	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	286	286	0	0	0	0	0	0	0	0	0	0
	地下水	4,173	4,167	6	0	0	0	0	0	0	0	0	0
	その他	1,928	1,928	0	0	0	0	0	0	0	0	0	0
ジェオスミン			～0.000001	～0.000002	～0.000004	～0.000006	～0.000008	～0.000010	～0.000012	～0.000014	～0.000016	～0.000020	0.000021～
	全体	8,548	8,252	217	61	15	1	1	0	1	0	0	0
	表流水	2,001	1,880	81	33	6	1	0	0	0	0	0	0
	ダム湖沼	308	266	28	11	2	0	0	0	1	0	0	0
	地下水	4,262	4,225	28	4	4	0	1	0	0	0	0	0
	その他	1,977	1,881	80	13	3	0	0	0	0	0	0	0
2-メチルイソボルネオール			～0.000001	～0.000002	～0.000004	～0.000006	～0.000008	～0.000010	～0.000012	～0.000014	～0.000016	～0.000020	0.000021～
	全体	8,547	8,466	58	18	2	2	0	0	0	1	0	0
	表流水	2,001	1,972	19	7	1	1	0	0	0	1	0	0
	ダム湖沼	308	296	7	4	0	1	0	0	0	0	0	0
	地下水	4,261	4,251	7	2	1	0	0	0	0	0	0	0
	その他	1,977	1,947	25	5	0	0	0	0	0	0	0	0
非イオン界面活性剤			～0.005	～0.006	～0.007	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	8,366	8,364	1	1	0	0	0	0	0	0	0	0
	表流水	1,898	1,898	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	287	287	0	0	0	0	0	0	0	0	0	0
	地下水	4,240	4,238	1	1	0	0	0	0	0	0	0	0
	その他	1,941	1,941	0	0	0	0	0	0	0	0	0	0
フェノール類			～0.0005	～0.0010	～0.0015	～0.0020	～0.0025	～0.0030	～0.0035	～0.0040	～0.0045	～0.0050	0.0051～
	全体	8,266	8,251	2	0	0	0	0	0	0	0	13	0
	表流水	1,881	1,880	0	0	0	0	0	0	0	0	1	0
	ダム湖沼	285	283	0	0	0	0	0	0	0	0	2	0
	地下水	4,173	4,163	2	0	0	0	0	0	0	0	8	0
	その他	1,927	1,925	0	0	0	0	0	0	0	0	2	0
有機物(TOCの量)			～0.5	0.6	0.7	0.8	0.9	1	～2.0	～3.0	～4.0	～5.0	5.1～
	全体	9,357	7,609	595	407	353	160	80	152	1	0	0	0
	表流水	2,132	1,438	288	163	110	48	29	56	0	0	0	0
	ダム湖沼	324	106	40	43	48	25	19	42	1	0	0	0
	地下水	4,732	4,394	141	74	64	26	19	14	0	0	0	0
	その他	2,169	1,671	126	127	131	61	13	40	0	0	0	0
pH値			～5.8	～6.0	～6.3	～6.6	～6.9	～7.2	～7.5	～7.8	～8.2	～8.6	8.7～
	全体	9,358	2	7	87	419	1,238	2,278	2,833	1,684	749	61	0
	表流水	2,132	0	0	1	30	179	628	809	368	109	8	0
	ダム湖沼	324	0	0	0	5	27	107	139	43	3	0	0
	地下水	4,733	1	4	72	317	843	1,067	1,094	796	490	49	0
	その他	2,169	1	3	14	67	189	476	791	477	147	4	0
味の異常回数			0	1	2	3	4	5	6	7	8	9	10～
	全体	9,358	9,357	1	0	0	0	0	0	0	0	0	0
	表流水	2,132	2,131	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	324	324	0	0	0	0	0	0	0	0	0	0
	地下水	4,733	4,733	0	0	0	0	0	0	0	0	0	0
	その他	2,169	2,169	0	0	0	0	0	0	0	0	0	0
臭気の異常回数			0	1	2	3	4	5	6	7	8	9	10～
	全体	9,358	9,352	3	1	0	1	1	0	0	0	0	0
	表流水	2,132	2,131	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	324	320	2	0	0	1	1	0	0	0	0	0
	地下水	4,733	4,733	0	0	0	0	0	0	0	0	0	0
	その他	2,169	2,168	0	1	0	0	0	0	0	0	0	0
色度			～0.5	～1.0	～1.5	～2.0	～2.5	～3.0	～3.5	～4.0	～4.5	～5.0	5.1～
	全体	9,358	8,495	692	114	41	11	5	0	0	0	0	0
	表流水	2,132	1,753	287	62	22	7	1	0	0	0	0	0
	ダム湖沼	324	273	44	5	2	0	0	0	0	0	0	0
	地下水	4,733	4,414	267	35	12	3	2	0	0	0	0	0
	その他	2,169	2,055	94	12	5	1	2	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
濁度			～0.1	～0.2	～0.4	～0.6	～0.8	～1.0	～1.2	～1.4	～1.6	～2.0	2.1～
全体		9,358	8,955	318	62	18	3	1	0	0	0	0	1
表流水		2,132	2,029	83	16	4	0	0	0	0	0	0	0
ダム湖沼		324	315	8	0	0	1	0	0	0	0	0	0
地下水		4,733	4,541	163	22	6	1	0	0	0	0	0	0
その他		2,169	2,070	64	24	8	1	1	0	0	0	0	1
アンチモン及びその化合物			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
全体		2,511	2,509	2	0	0	0	0	0	0	0	0	0
表流水		599	599	0	0	0	0	0	0	0	0	0	0
ダム湖沼		135	135	0	0	0	0	0	0	0	0	0	0
地下水		1,161	1,159	2	0	0	0	0	0	0	0	0	0
その他		616	616	0	0	0	0	0	0	0	0	0	0
ウラン及びその化合物			～0.0002	～0.0004	～0.0006	～0.0008	～0.0010	～0.0012	～0.0014	～0.0016	～0.0018	～0.0020	0.0021～
全体		2,499	2,449	36	6	4	1	0	0	0	1	2	0
表流水		593	589	3	0	0	1	0	0	0	0	0	0
ダム湖沼		131	131	0	0	0	0	0	0	0	0	0	0
地下水		1,161	1,121	28	6	3	0	0	0	0	1	2	0
その他		614	608	5	0	1	0	0	0	0	0	0	0
ニッケル及びその化合物			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
全体		2,762	2,748	10	1	1	2	0	0	0	0	0	0
表流水		652	648	3	0	1	0	0	0	0	0	0	0
ダム湖沼		154	153	1	0	0	0	0	0	0	0	0	0
地下水		1,254	1,247	5	1	0	1	0	0	0	0	0	0
その他		702	700	1	0	0	1	0	0	0	0	0	0
1,2-ジクロロエタン			～0.0004	～0.0008	～0.0012	～0.0016	～0.0020	～0.0024	～0.0028	～0.0032	～0.0036	～0.0040	0.0041～
全体		2,386	2,385	0	0	0	0	0	0	0	0	1	0
表流水		556	556	0	0	0	0	0	0	0	0	0	0
ダム湖沼		122	122	0	0	0	0	0	0	0	0	0	0
地下水		1,109	1,108	0	0	0	0	0	0	0	0	1	0
その他		599	599	0	0	0	0	0	0	0	0	0	0
トルエン			～0.040	～0.080	～0.120	～0.160	～0.200	～0.240	～0.280	～0.320	～0.360	～0.400	0.401～
全体		2,429	2,429	0	0	0	0	0	0	0	0	0	0
表流水		559	559	0	0	0	0	0	0	0	0	0	0
ダム湖沼		124	124	0	0	0	0	0	0	0	0	0	0
地下水		1,151	1,151	0	0	0	0	0	0	0	0	0	0
その他		595	595	0	0	0	0	0	0	0	0	0	0
フタル酸ジ(2-エチルヘキシル)			～0.008	～0.016	～0.024	～0.032	～0.040	～0.048	～0.056	～0.064	～0.072	～0.080	0.081～
全体		2,245	2,244	1	0	0	0	0	0	0	0	0	0
表流水		516	516	0	0	0	0	0	0	0	0	0	0
ダム湖沼		118	118	0	0	0	0	0	0	0	0	0	0
地下水		1,047	1,046	1	0	0	0	0	0	0	0	0	0
その他		564	564	0	0	0	0	0	0	0	0	0	0
亜塩素酸			～0.06	～0.12	～0.18	～0.24	～0.30	～0.36	～0.42	～0.48	～0.54	～0.60	0.61～
全体		1,302	1,298	3	1	0	0	0	0	0	0	0	0
表流水		306	306	0	0	0	0	0	0	0	0	0	0
ダム湖沼		89	89	0	0	0	0	0	0	0	0	0	0
地下水		700	697	2	1	0	0	0	0	0	0	0	0
その他		207	206	1	0	0	0	0	0	0	0	0	0
二酸化塩素			～0.06	～0.12	～0.18	～0.24	～0.30	～0.36	～0.42	～0.48	～0.54	～0.60	0.61～
全体		639	639	0	0	0	0	0	0	0	0	0	0
表流水		121	121	0	0	0	0	0	0	0	0	0	0
ダム湖沼		18	18	0	0	0	0	0	0	0	0	0	0
地下水		410	410	0	0	0	0	0	0	0	0	0	0
その他		90	90	0	0	0	0	0	0	0	0	0	0
ジクロロアセトニトリル			～0.004	～0.008	～0.012	～0.016	～0.020	～0.024	～0.028	～0.032	～0.036	～0.040	0.041～
全体		3,098	3,094	4	0	0	0	0	0	0	0	0	0
表流水		736	734	2	0	0	0	0	0	0	0	0	0
ダム湖沼		171	171	0	0	0	0	0	0	0	0	0	0
地下水		1,458	1,458	0	0	0	0	0	0	0	0	0	0
その他		733	731	2	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
抱水クロラール			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	3,099	2,660	354	66	14	2	1	2	0	0	0	0
	表流水	736	575	123	28	8	2	0	0	0	0	0	0
	ダム湖沼	171	117	41	8	4	0	1	0	0	0	0	0
	地下水	1,459	1,411	42	3	2	0	0	1	0	0	0	0
	その他	733	557	148	27	0	0	0	1	0	0	0	0
農薬類			～0.01	～0.02	～0.03	～0.05	～0.10	～0.20	～0.30	～0.50	～0.70	～1.00	1.01～
	全体	890	885	1	0	0	1	0	0	0	0	3	0
	表流水	223	223	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	39	38	0	0	0	0	0	0	0	0	1	0
	地下水	432	429	0	0	0	1	0	0	0	0	2	0
	その他	196	195	1	0	0	0	0	0	0	0	0	0
残留塩素			<0.1	0.1	0.2	0.3	0.4	0.5	0.6	～0.8	～1.0	～1.2	1.3～
	全体	9,151	17	313	2,123	2,877	1,974	1,053	446	296	46	2	4
	表流水	2,075	4	36	323	552	533	326	166	118	15	1	1
	ダム湖沼	317	0	6	31	63	74	67	31	37	7	0	1
	地下水	4,621	9	192	1,287	1,609	899	409	137	68	10	1	0
	その他	2,138	4	79	482	653	468	251	112	73	14	0	2
遊離炭酸			～2.0	～4.0	～6.0	～8.0	～10.0	～12.0	～14.0	～16.0	～18.0	～20.0	20.1～
	全体	2,861	791	929	438	210	131	82	65	53	40	30	92
	表流水	646	269	255	80	17	9	4	2	2	0	3	5
	ダム湖沼	150	42	67	25	10	5	1	0	0	0	0	0
	地下水	1,383	285	337	215	135	106	60	54	45	38	24	84
	その他	682	195	270	118	48	11	17	9	6	2	3	3
1,1,1-トリクロロエタン			～0.030	～0.060	～0.090	～0.120	～0.150	～0.180	～0.210	～0.240	～0.270	～0.300	0.301～
	全体	2,512	2,512	0	0	0	0	0	0	0	0	0	0
	表流水	604	604	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	131	131	0	0	0	0	0	0	0	0	0	0
	地下水	1,150	1,150	0	0	0	0	0	0	0	0	0	0
	その他	627	627	0	0	0	0	0	0	0	0	0	0
メチル-tert-ブチルエーテル(MTBE)			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	2,407	2,407	0	0	0	0	0	0	0	0	0	0
	表流水	558	558	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	116	116	0	0	0	0	0	0	0	0	0	0
	地下水	1,144	1,144	0	0	0	0	0	0	0	0	0	0
	その他	589	589	0	0	0	0	0	0	0	0	0	0
有機物等(過マンガン酸カリウム消費量)			～0.3	～0.6	～0.9	～1.2	～1.5	～1.8	～2.1	～2.4	～2.7	～3.0	3.1～
	全体	1,882	403	295	371	289	202	125	97	47	27	14	12
	表流水	427	39	48	79	63	59	49	39	21	14	7	9
	ダム湖沼	107	2	6	16	20	18	15	14	8	4	3	1
	地下水	874	261	183	191	120	68	21	13	8	4	3	2
	その他	474	101	58	85	86	57	40	31	10	5	1	0
臭気強度(TON)			0	1	2	3	4	5	6	～8	～10	～15	16～
	全体	2,463	2,088	295	59	14	5	1	1	0	0	0	0
	表流水	582	473	72	28	5	3	1	0	0	0	0	0
	ダム湖沼	138	112	18	6	1	0	0	1	0	0	0	0
	地下水	1,133	1,006	108	13	4	2	0	0	0	0	0	0
	その他	610	497	97	12	4	0	0	0	0	0	0	0
腐食性(ランゲリア指数)			～-4.0	～-3.5	～-3.0	～-2.5	～-2.0	～-1.5	～-1.0	～-0.5	～0.0	～0.5	0.6～
	全体	2,790	7	23	64	162	404	734	749	405	142	32	68
	表流水	640	3	15	31	67	100	197	159	45	17	1	5
	ダム湖沼	153	0	2	1	20	26	46	38	14	2	0	4
	地下水	1,318	2	2	22	43	161	325	360	235	101	21	46
	その他	679	2	4	10	32	117	166	192	111	22	10	13
従属栄養細菌			0	～200	～400	～600	～800	～1000	～1200	～1400	～1600	～2000	2001～
	全体	3,080	1,303	1,752	14	6	3	1	0	0	0	0	1
	表流水	746	413	330	2	0	0	1	0	0	0	0	0
	ダム湖沼	169	101	68	0	0	0	0	0	0	0	0	0
	地下水	1,439	434	989	10	3	2	0	0	0	0	0	1
	その他	726	355	365	2	3	1	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
1,1-ジクロロエチレン			~0.002	~0.004	~0.006	~0.008	~0.010	~0.012	~0.014	~0.016	~0.018	~0.020	0.021~
	全体	2,494	2,470	0	0	0	23	0	0	0	0	0	1
	表流水	590	586	0	0	0	4	0	0	0	0	0	0
	ダム湖沼	122	122	0	0	0	0	0	0	0	0	0	0
	地下水	1,169	1,151	0	0	0	17	0	0	0	0	0	1
	その他	613	611	0	0	0	2	0	0	0	0	0	0
ペルフルオロオクタン SULFON 基(PFOS) 及びペルフルオロオクタン 基(PFOA)			~0.000005	~0.000010	~0.000015	~0.000020	~0.000025	~0.000030	~0.000035	~0.000040	~0.000045	~0.000050	0.000051~
	全体	1,963	1,790	99	34	12	10	7	6	2	0	1	2
	表流水	462	444	14	2	0	1	0	1	0	0	0	0
	ダム湖沼	95	89	4	1	0	0	0	0	0	0	0	1
	地下水	1,031	909	58	29	10	9	7	5	2	0	1	1
	その他	375	348	23	2	2	0	0	0	0	0	0	0
1,3-ジクロロプロペン (D-D)			~0.0005	~0.0010	~0.0015	~0.0025	~0.0035	~0.0050	~0.0150	~0.0250	~0.0350	~0.0500	0.0501~
	全体	710	709	1	0	0	0	0	0	0	0	0	0
	表流水	182	182	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	353	352	1	0	0	0	0	0	0	0	0	0
	その他	141	141	0	0	0	0	0	0	0	0	0	0
2,2-DPA(ダラボン)			~0.0008	~0.0016	~0.0024	~0.0040	~0.0056	~0.0080	~0.0240	~0.0400	~0.0560	~0.0800	0.0801~
	全体	434	425	9	0	0	0	0	0	0	0	0	0
	表流水	132	130	2	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	198	191	7	0	0	0	0	0	0	0	0	0
	その他	78	78	0	0	0	0	0	0	0	0	0	0
2,4-D(2,4-PA)			~0.0002	~0.0004	~0.0006	~0.0010	~0.0014	~0.0020	~0.0060	~0.0100	~0.0140	~0.0200	0.0201~
	全体	623	623	0	0	0	0	0	0	0	0	0	0
	表流水	178	178	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	297	297	0	0	0	0	0	0	0	0	0	0
	その他	114	114	0	0	0	0	0	0	0	0	0	0
EPN			~0.00006	~0.00012	~0.00018	~0.00030	~0.00042	~0.00060	~0.00180	~0.00300	~0.00420	~0.00600	0.00601~
	全体	658	658	0	0	0	0	0	0	0	0	0	0
	表流水	171	171	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	316	316	0	0	0	0	0	0	0	0	0	0
	その他	139	139	0	0	0	0	0	0	0	0	0	0
MCPA			~0.0005	~0.0010	~0.0015	~0.0020	~0.0025	~0.0030	~0.0035	~0.00400	~0.0045	~0.0050	0.0051~
	全体	542	542	0	0	0	0	0	0	0	0	0	0
	表流水	149	149	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	243	243	0	0	0	0	0	0	0	0	0	0
	その他	116	116	0	0	0	0	0	0	0	0	0	0
アシュラム			~0.009	~0.018	~0.027	~0.045	~0.063	~0.090	~0.270	~0.450	~0.630	~0.90	0.901~
	全体	559	559	0	0	0	0	0	0	0	0	0	0
	表流水	154	154	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	263	263	0	0	0	0	0	0	0	0	0	0
	その他	108	108	0	0	0	0	0	0	0	0	0	0
アセフェート			~0.0008	~0.0016	~0.0024	~0.0040	~0.0056	~0.0080	~0.0240	~0.0400	~0.0560	~0.0800	0.0801~
	全体	646	646	0	0	0	0	0	0	0	0	0	0
	表流水	174	174	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	28	0	0	0	0	0	0	0	0	0	0
	地下水	317	317	0	0	0	0	0	0	0	0	0	0
	その他	127	127	0	0	0	0	0	0	0	0	0	0
アトラジン			~0.0001	~0.0002	~0.0003	~0.0005	~0.0007	~0.0010	~0.0030	~0.0050	~0.0070	~0.010	0.0101~
	全体	673	673	0	0	0	0	0	0	0	0	0	0
	表流水	169	169	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	327	327	0	0	0	0	0	0	0	0	0	0
	その他	145	145	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
アニロホス			～0.00003	～0.00006	～0.00009	～0.00015	～0.00021	～0.00030	～0.00090	～0.00150	～0.00210	～0.00300	0.00301～
	全体	572	568	4	0	0	0	0	0	0	0	0	0
	表流水	157	157	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	261	257	4	0	0	0	0	0	0	0	0	0
	その他	122	122	0	0	0	0	0	0	0	0	0	0
アミトラズ			～0.0006	～0.0012	～0.0018	～0.0024	～0.0030	～0.0036	～0.0042	～0.0048	～0.0054	～0.0060	0.0061～
	全体	484	484	0	0	0	0	0	0	0	0	0	0
	表流水	130	130	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	238	238	0	0	0	0	0	0	0	0	0	0
	その他	90	90	0	0	0	0	0	0	0	0	0	0
アラクロール			～0.0001	～0.0002	～0.0003	～0.0005	～0.0007	～0.0010	～0.0030	～0.0050	～0.0070	～0.010	0.0101～
	全体	677	665	0	12	0	0	0	0	0	0	0	0
	表流水	171	170	0	1	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	329	318	0	11	0	0	0	0	0	0	0	0
	その他	144	144	0	0	0	0	0	0	0	0	0	0
イソキサチオン			～0.00005	～0.00010	～0.00015	～0.00025	～0.00035	～0.00050	～0.00150	～0.00250	～0.00350	～0.00500	0.00501～
	全体	758	758	0	0	0	0	0	0	0	0	0	0
	表流水	199	199	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	27	27	0	0	0	0	0	0	0	0	0	0
	地下水	369	369	0	0	0	0	0	0	0	0	0	0
	その他	163	163	0	0	0	0	0	0	0	0	0	0
イソフェンホス			～0.00001	～0.00002	～0.00003	～0.00005	～0.00007	～0.00010	～0.00030	～0.00050	～0.00070	～0.00100	0.00101～
	全体	568	559	4	5	0	0	0	0	0	0	0	0
	表流水	157	156	0	1	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	266	258	4	4	0	0	0	0	0	0	0	0
	その他	119	119	0	0	0	0	0	0	0	0	0	0
イソプロカルブ (MIPC)			～0.0001	～0.0002	～0.0003	～0.0005	～0.0007	～0.0010	～0.0030	～0.0050	～0.0070	～0.010	0.0101～
	全体	589	589	0	0	0	0	0	0	0	0	0	0
	表流水	166	166	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	262	262	0	0	0	0	0	0	0	0	0	0
	その他	129	129	0	0	0	0	0	0	0	0	0	0
イソプロチオラン (IPT)			～0.0004	～0.0008	～0.0012	～0.0020	～0.0028	～0.0040	～0.0120	～0.0200	～0.0280	～0.0400	0.0401～
	全体	698	685	0	0	0	0	13	0	0	0	0	0
	表流水	179	178	0	0	0	0	1	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	344	333	0	0	0	0	11	0	0	0	0	0
	その他	141	140	0	0	0	0	1	0	0	0	0	0
イブフェンカルバゾン			～0.00002	～0.00004	～0.00006	～0.00010	～0.00014	～0.00020	～0.00060	～0.00100	～0.00140	～0.00200	0.00201～
	全体	573	571	0	1	0	0	0	1	0	0	0	0
	表流水	159	159	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	27	0	1	0	0	0	0	0	0	0	0
	地下水	272	271	0	0	0	0	0	1	0	0	0	0
	その他	114	114	0	0	0	0	0	0	0	0	0	0
イプロベンホス (IBP)			～0.00008	～0.00016	～0.00024	～0.00040	～0.00056	～0.00080	～0.00240	～0.00400	～0.00560	～0.00800	0.00801～
	全体	639	627	0	0	0	0	0	12	0	0	0	0
	表流水	168	167	0	0	0	0	0	1	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	306	295	0	0	0	0	0	11	0	0	0	0
	その他	133	133	0	0	0	0	0	0	0	0	0	0
イミノクタジン			～0.00006	～0.00012	～0.00018	～0.00030	～0.00042	～0.00060	～0.00180	～0.00300	～0.00420	～0.00600	0.00601～
	全体	536	536	0	0	0	0	0	0	0	0	0	0
	表流水	152	152	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	22	22	0	0	0	0	0	0	0	0	0	0
	地下水	252	252	0	0	0	0	0	0	0	0	0	0
	その他	110	110	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
インダノファン			～0.0009	～0.0018	～0.0027	～0.0036	～0.0045	～0.0054	～0.0063	～0.0072	～0.0081	～0.0090	0.0091～
	全体	564	564	0	0	0	0	0	0	0	0	0	0
	表流水	147	147	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	278	278	0	0	0	0	0	0	0	0	0	0
	その他	107	107	0	0	0	0	0	0	0	0	0	0
エスプロカルブ			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	663	663	0	0	0	0	0	0	0	0	0	0
	表流水	178	178	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	306	306	0	0	0	0	0	0	0	0	0	0
	その他	146	146	0	0	0	0	0	0	0	0	0	0
イトフェンプロックス			～0.0008	～0.0016	～0.0024	～0.0040	～0.0056	～0.0080	～0.0240	～0.0400	～0.0560	～0.0800	0.0801～
	全体	797	797	0	0	0	0	0	0	0	0	0	0
	表流水	208	208	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	394	394	0	0	0	0	0	0	0	0	0	0
	その他	161	161	0	0	0	0	0	0	0	0	0	0
エンドスルファン(ベンゾエピン)			～0.0001	～0.0002	～0.0003	～0.0005	～0.0007	～0.0010	～0.0030	～0.0050	～0.0070	～0.010	0.0101～
	全体	490	490	0	0	0	0	0	0	0	0	0	0
	表流水	136	136	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	228	228	0	0	0	0	0	0	0	0	0	0
	その他	100	100	0	0	0	0	0	0	0	0	0	0
オキサジクロメホン			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	598	598	0	0	0	0	0	0	0	0	0	0
	表流水	152	152	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	35	35	0	0	0	0	0	0	0	0	0	0
	地下水	293	293	0	0	0	0	0	0	0	0	0	0
	その他	118	118	0	0	0	0	0	0	0	0	0	0
オキシ銅(有機銅)			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	562	562	0	0	0	0	0	0	0	0	0	0
	表流水	147	147	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	28	0	0	0	0	0	0	0	0	0	0
	地下水	279	279	0	0	0	0	0	0	0	0	0	0
	その他	108	108	0	0	0	0	0	0	0	0	0	0
オリサストロビン			～0.01	～0.02	～0.03	～0.04	～0.05	～0.06	～0.07	～0.08	～0.09	～0.10	0.11～
	全体	461	461	0	0	0	0	0	0	0	0	0	0
	表流水	131	131	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	216	216	0	0	0	0	0	0	0	0	0	0
	その他	88	88	0	0	0	0	0	0	0	0	0	0
カズサホス			～0.00006	～0.00012	～0.00018	～0.00030	～0.00042	～0.00060	～0.00180	～0.00300	～0.00420	～0.00600	0.00601～
	全体	526	526	0	0	0	0	0	0	0	0	0	0
	表流水	138	138	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	248	248	0	0	0	0	0	0	0	0	0	0
	その他	108	108	0	0	0	0	0	0	0	0	0	0
カフェンストロール			～0.00008	～0.00016	～0.00024	～0.00040	～0.00056	～0.00080	～0.00240	～0.00400	～0.00560	～0.00800	0.00801～
	全体	714	714	0	0	0	0	0	0	0	0	0	0
	表流水	176	176	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	348	348	0	0	0	0	0	0	0	0	0	0
	その他	156	156	0	0	0	0	0	0	0	0	0	0
カルタツブ			～0.0008	～0.0016	～0.0024	～0.0040	～0.0056	～0.0080	～0.0240	～0.0400	～0.0560	～0.0800	0.0801～
	全体	520	519	1	0	0	0	0	0	0	0	0	0
	表流水	131	131	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	28	0	0	0	0	0	0	0	0	0	0
	地下水	268	267	1	0	0	0	0	0	0	0	0	0
	その他	93	93	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
カルバリル (NAC)			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	575	575	0	0	0	0	0	0	0	0	0	0
	表流水	171	171	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	273	273	0	0	0	0	0	0	0	0	0	0
	その他	99	99	0	0	0	0	0	0	0	0	0	0
カルボフラン			～0.000003	～0.000006	～0.000009	～0.000015	～0.000021	～0.000030	～0.000090	～0.000150	～0.000210	～0.000300	0.000301～
	全体	522	518	2	0	0	0	2	0	0	0	0	0
	表流水	148	148	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	33	0	0	0	0	1	0	0	0	0	0
	地下水	231	228	2	0	0	0	1	0	0	0	0	0
	その他	109	109	0	0	0	0	0	0	0	0	0	0
キノクラミン (ACN)			～0.0005	～0.0010	～0.0015	～0.0020	～0.0025	～0.0030	～0.0035	～0.0040	～0.0045	～0.0050	0.0051～
	全体	538	538	0	0	0	0	0	0	0	0	0	0
	表流水	164	164	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	238	238	0	0	0	0	0	0	0	0	0	0
	その他	102	102	0	0	0	0	0	0	0	0	0	0
キャプタン			～0.003	～0.006	～0.009	～0.015	～0.021	～0.030	～0.090	～0.150	～0.210	～0.300	0.301～
	全体	647	646	0	0	0	0	1	0	0	0	0	0
	表流水	168	168	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	314	313	0	0	0	0	1	0	0	0	0	0
	その他	132	132	0	0	0	0	0	0	0	0	0	0
クミルロン			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	570	570	0	0	0	0	0	0	0	0	0	0
	表流水	150	150	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	281	281	0	0	0	0	0	0	0	0	0	0
	その他	107	107	0	0	0	0	0	0	0	0	0	0
グリホサート			～0.02	～0.04	～0.06	～0.10	～0.14	～0.20	～0.60	～1.00	～1.40	～2.00	2.01～
	全体	634	634	0	0	0	0	0	0	0	0	0	0
	表流水	175	175	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	28	0	0	0	0	0	0	0	0	0	0
	地下水	304	304	0	0	0	0	0	0	0	0	0	0
	その他	127	127	0	0	0	0	0	0	0	0	0	0
グルホシネート			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	520	520	0	0	0	0	0	0	0	0	0	0
	表流水	150	150	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	244	244	0	0	0	0	0	0	0	0	0	0
	その他	100	100	0	0	0	0	0	0	0	0	0	0
クロメプロップ			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	519	519	0	0	0	0	0	0	0	0	0	0
	表流水	148	148	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	235	235	0	0	0	0	0	0	0	0	0	0
	その他	104	104	0	0	0	0	0	0	0	0	0	0
クロルニトロフェン (GNP)			～0.000001	～0.000002	～0.000003	～0.000005	～0.000007	～0.000010	～0.000030	～0.000050	～0.000070	～0.000100	0.000101～
	全体	512	500	0	0	0	0	3	0	0	0	9	0
	表流水	143	142	0	0	0	0	0	0	0	0	1	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	238	228	0	0	0	0	3	0	0	0	7	0
	その他	105	104	0	0	0	0	0	0	0	0	1	0
クロルピリホス			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	716	716	0	0	0	0	0	0	0	0	0	0
	表流水	194	194	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	27	27	0	0	0	0	0	0	0	0	0	0
	地下水	348	348	0	0	0	0	0	0	0	0	0	0
	その他	147	147	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
クロロタロニル (TPN)			~0.0005	~0.0010	~0.0015	~0.0025	~0.0035	~0.0050	~0.0150	~0.0250	~0.0350	~0.0500	0.0501~
	全体	721	717	0	0	0	4	0	0	0	0	0	0
	表流水	178	178	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	31	31	0	0	0	0	0	0	0	0	0	0
	地下水	355	352	0	0	0	3	0	0	0	0	0	0
	その他	157	156	0	0	0	1	0	0	0	0	0	0
シアナジン			~0.00001	~0.00002	~0.00003	~0.00005	~0.00007	~0.00010	~0.00030	~0.00050	~0.00070	~0.00100	0.00101~
	全体	583	583	0	0	0	0	0	0	0	0	0	0
	表流水	150	150	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	277	277	0	0	0	0	0	0	0	0	0	0
	その他	124	124	0	0	0	0	0	0	0	0	0	0
シアノホス(CYAP)			~0.0003	~0.0006	~0.0009	~0.0012	~0.0015	~0.0018	~0.0021	~0.0024	~0.0027	~0.0030	0.0031~
	全体	537	537	0	0	0	0	0	0	0	0	0	0
	表流水	144	144	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	244	244	0	0	0	0	0	0	0	0	0	0
	その他	117	117	0	0	0	0	0	0	0	0	0	0
ジウロン (DCMU)			~0.0002	~0.0004	~0.0006	~0.0010	~0.0014	~0.0020	~0.0060	~0.0100	~0.0140	~0.0200	0.0201~
	全体	584	584	0	0	0	0	0	0	0	0	0	0
	表流水	154	154	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	284	284	0	0	0	0	0	0	0	0	0	0
	その他	112	112	0	0	0	0	0	0	0	0	0	0
ジクロベニル (DBN)			~0.0003	~0.0006	~0.0009	~0.0015	~0.0021	~0.0030	~0.0090	~0.0150	~0.0210	~0.0300	0.0301~
	全体	690	690	0	0	0	0	0	0	0	0	0	0
	表流水	179	179	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	337	337	0	0	0	0	0	0	0	0	0	0
	その他	148	148	0	0	0	0	0	0	0	0	0	0
ジクロロボス (DDVP)			~0.00008	~0.00016	~0.00024	~0.00040	~0.00056	~0.00080	~0.00240	~0.00400	~0.00560	~0.00800	0.00801~
	全体	620	616	0	0	4	0	0	0	0	0	0	0
	表流水	162	162	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	305	301	0	0	4	0	0	0	0	0	0	0
	その他	127	127	0	0	0	0	0	0	0	0	0	0
ジクワット			~0.0001	~0.0002	~0.0003	~0.0005	~0.0007	~0.0010	~0.0030	~0.0050	~0.0070	~0.0100	0.0101~
	全体	586	585	0	0	0	0	0	0	0	0	1	0
	表流水	160	160	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	22	22	0	0	0	0	0	0	0	0	0	0
	地下水	289	288	0	0	0	0	0	0	0	0	1	0
	その他	115	115	0	0	0	0	0	0	0	0	0	0
ジスルホトン(エチルチオメトン)			~0.00004	~0.00008	~0.00012	~0.00020	~0.00028	~0.00040	~0.00120	~0.00200	~0.00280	~0.00400	0.00401~
	全体	622	618	0	0	0	0	4	0	0	0	0	0
	表流水	161	161	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	298	294	0	0	0	0	4	0	0	0	0	0
	その他	137	137	0	0	0	0	0	0	0	0	0	0
ジチオカルバメート系農薬			~0.0005	~0.0010	~0.0015	~0.0020	~0.0025	~0.0030	~0.0035	~0.0040	~0.0045	~0.0050	0.0051~
	全体	456	456	0	0	0	0	0	0	0	0	0	0
	表流水	130	130	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	18	18	0	0	0	0	0	0	0	0	0	0
	地下水	217	217	0	0	0	0	0	0	0	0	0	0
	その他	91	91	0	0	0	0	0	0	0	0	0	0
ジチオピル			~0.00008	~0.00016	~0.00024	~0.00040	~0.00056	~0.00080	~0.00240	~0.00400	~0.00560	~0.00800	0.00801~
	全体	581	569	12	0	0	0	0	0	0	0	0	0
	表流水	159	158	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	276	265	11	0	0	0	0	0	0	0	0	0
	その他	120	120	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
シハロホップブチル			～0.0006	～0.0012	～0.0018	～0.0024	～0.0030	～0.0036	～0.0042	～0.0048	～0.0054	～0.0060	0.0061～
	全体	563	563	0	0	0	0	0	0	0	0	0	0
	表流水	147	147	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	276	276	0	0	0	0	0	0	0	0	0	0
	その他	106	106	0	0	0	0	0	0	0	0	0	0
シマジン (CAT)			～0.00003	～0.00006	～0.00009	～0.00015	～0.00021	～0.00030	～0.00090	～0.00150	～0.00210	～0.00300	0.00301～
	全体	755	755	0	0	0	0	0	0	0	0	0	0
	表流水	200	200	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	365	365	0	0	0	0	0	0	0	0	0	0
	その他	157	157	0	0	0	0	0	0	0	0	0	0
ジメタメトリン			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	729	729	0	0	0	0	0	0	0	0	0	0
	表流水	208	208	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	37	37	0	0	0	0	0	0	0	0	0	0
	地下水	339	339	0	0	0	0	0	0	0	0	0	0
	その他	145	145	0	0	0	0	0	0	0	0	0	0
ジメトエート			～0.0005	～0.0010	～0.0015	～0.0025	～0.0035	～0.0050	～0.0150	～0.0250	～0.0350	～0.0500	0.0501～
	全体	597	597	0	0	0	0	0	0	0	0	0	0
	表流水	163	163	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	277	277	0	0	0	0	0	0	0	0	0	0
	その他	125	125	0	0	0	0	0	0	0	0	0	0
シメトリン			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	785	785	0	0	0	0	0	0	0	0	0	0
	表流水	213	213	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	38	38	0	0	0	0	0	0	0	0	0	0
	地下水	368	368	0	0	0	0	0	0	0	0	0	0
	その他	166	166	0	0	0	0	0	0	0	0	0	0
ダイアジノン			～0.00003	～0.00006	～0.00009	～0.00015	～0.00021	～0.00030	～0.00090	～0.00150	～0.00210	～0.00300	0.00301～
	全体	817	817	0	0	0	0	0	0	0	0	0	0
	表流水	207	207	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	402	402	0	0	0	0	0	0	0	0	0	0
	その他	174	174	0	0	0	0	0	0	0	0	0	0
ダイムロン			～0.008	～0.016	～0.024	～0.040	～0.056	～0.080	～0.240	～0.400	～0.560	～0.800	0.801～
	全体	642	642	0	0	0	0	0	0	0	0	0	0
	表流水	192	192	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	38	38	0	0	0	0	0	0	0	0	0	0
	地下水	299	299	0	0	0	0	0	0	0	0	0	0
	その他	113	113	0	0	0	0	0	0	0	0	0	0
ダゾメット、メタム(カーバム)及びメチルイソチオシアネート			～0.0001	～0.0002	～0.0003	～0.0005	～0.0007	～0.0010	～0.0030	～0.0050	～0.0070	～0.010	0.0101～
	全体	486	486	0	0	0	0	0	0	0	0	0	0
	表流水	124	124	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	22	22	0	0	0	0	0	0	0	0	0	0
	地下水	243	243	0	0	0	0	0	0	0	0	0	0
	その他	97	97	0	0	0	0	0	0	0	0	0	0
チアジニル			～0.01	～0.02	～0.03	～0.04	～0.05	～0.06	～0.07	～0.08	～0.09	～0.10	0.11～
	全体	540	540	0	0	0	0	0	0	0	0	0	0
	表流水	148	148	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	253	253	0	0	0	0	0	0	0	0	0	0
	その他	107	107	0	0	0	0	0	0	0	0	0	0
チウラム			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	684	684	0	0	0	0	0	0	0	0	0	0
	表流水	178	178	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	339	339	0	0	0	0	0	0	0	0	0	0
	その他	133	133	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
チオジカルブ			～0.0008	～0.0016	～0.0024	～0.0040	～0.0056	～0.0080	～0.0240	～0.0400	～0.0560	～0.0800	0.0801～
	全体	535	535	0	0	0	0	0	0	0	0	0	0
	表流水	148	148	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	31	31	0	0	0	0	0	0	0	0	0	0
	地下水	261	261	0	0	0	0	0	0	0	0	0	0
	その他	95	95	0	0	0	0	0	0	0	0	0	0
チオファネートメチル			～0.003	～0.006	～0.009	～0.015	～0.021	～0.030	～0.090	～0.150	～0.210	～0.300	0.301～
	全体	620	620	0	0	0	0	0	0	0	0	0	0
	表流水	171	171	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	28	0	0	0	0	0	0	0	0	0	0
	地下水	309	309	0	0	0	0	0	0	0	0	0	0
	その他	112	112	0	0	0	0	0	0	0	0	0	0
チオベンカルブ			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	670	670	0	0	0	0	0	0	0	0	0	0
	表流水	167	167	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	328	328	0	0	0	0	0	0	0	0	0	0
	その他	143	143	0	0	0	0	0	0	0	0	0	0
テフリルトリオン			～0.00002	～0.00004	～0.00006	～0.00010	～0.00014	～0.00020	～0.00060	～0.00100	～0.00140	～0.00200	0.00201～
	全体	563	562	0	0	0	0	0	1	0	0	0	0
	表流水	163	163	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	30	30	0	0	0	0	0	0	0	0	0	0
	地下水	264	263	0	0	0	0	0	1	0	0	0	0
	その他	106	106	0	0	0	0	0	0	0	0	0	0
テルブカルブ (MBPMC)			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	569	569	0	0	0	0	0	0	0	0	0	0
	表流水	156	156	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	258	258	0	0	0	0	0	0	0	0	0	0
	その他	123	123	0	0	0	0	0	0	0	0	0	0
トリクロピル			～0.00006	～0.00012	～0.00018	～0.00030	～0.00042	～0.00060	～0.00180	～0.00300	～0.00420	～0.00600	0.00601～
	全体	570	566	0	0	4	0	0	0	0	0	0	0
	表流水	149	149	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	277	273	0	0	4	0	0	0	0	0	0	0
	その他	112	112	0	0	0	0	0	0	0	0	0	0
トリクロルホン (DEP)			～0.00005	～0.00010	～0.00015	～0.00025	～0.00035	～0.00050	～0.00150	～0.00250	～0.00350	～0.00500	0.00501～
	全体	583	583	0	0	0	0	0	0	0	0	0	0
	表流水	145	145	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	293	293	0	0	0	0	0	0	0	0	0	0
	その他	119	119	0	0	0	0	0	0	0	0	0	0
トリシクラゾール			～0.001	～0.002	～0.003	～0.005	～0.007	～0.010	～0.030	～0.050	～0.070	～0.100	0.101～
	全体	608	608	0	0	0	0	0	0	0	0	0	0
	表流水	180	180	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	35	35	0	0	0	0	0	0	0	0	0	0
	地下水	291	291	0	0	0	0	0	0	0	0	0	0
	その他	102	102	0	0	0	0	0	0	0	0	0	0
トリフルラリン			～0.0006	～0.0012	～0.0018	～0.0030	～0.0042	～0.0060	～0.0180	～0.0300	～0.0420	～0.0600	0.0601～
	全体	703	702	0	0	1	0	0	0	0	0	0	0
	表流水	176	176	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	342	341	0	0	1	0	0	0	0	0	0	0
	その他	152	152	0	0	0	0	0	0	0	0	0	0
ナプロパミド			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	577	577	0	0	0	0	0	0	0	0	0	0
	表流水	156	156	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	264	264	0	0	0	0	0	0	0	0	0	0
	その他	125	125	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
パラコート			～0.0005	～0.0010	～0.0015	～0.0020	～0.0025	～0.0030	～0.0035	～0.0040	～0.0045	～0.0050	0.0051～
	全体	565	565	0	0	0	0	0	0	0	0	0	0
	表流水	153	153	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	22	22	0	0	0	0	0	0	0	0	0	0
	地下水	274	274	0	0	0	0	0	0	0	0	0	0
	その他	116	116	0	0	0	0	0	0	0	0	0	0
ピペロホス			～0.000009	～0.000018	～0.000027	～0.000045	～0.000063	～0.000090	～0.000270	～0.000450	～0.000630	～0.000900	0.000901～
	全体	550	541	0	0	2	7	0	0	0	0	0	0
	表流水	148	147	0	0	0	1	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	250	242	0	0	2	6	0	0	0	0	0	0
	その他	120	120	0	0	0	0	0	0	0	0	0	0
ピラクロニル			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	525	524	0	1	0	0	0	0	0	0	0	0
	表流水	141	141	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	29	29	0	0	0	0	0	0	0	0	0	0
	地下水	250	249	0	1	0	0	0	0	0	0	0	0
	その他	105	105	0	0	0	0	0	0	0	0	0	0
ピラゾキシフェン			～0.0004	～0.0008	～0.0012	～0.0016	～0.0020	～0.0024	～0.0028	～0.0032	～0.0036	～0.0040	0.0041～
	全体	497	497	0	0	0	0	0	0	0	0	0	0
	表流水	135	135	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	238	238	0	0	0	0	0	0	0	0	0	0
	その他	98	98	0	0	0	0	0	0	0	0	0	0
ピラゾリネート(ピラゾレート)			～0.002	～0.004	～0.006	～0.008	～0.010	～0.012	～0.014	～0.016	～0.018	～0.020	0.021～
	全体	594	594	0	0	0	0	0	0	0	0	0	0
	表流水	153	153	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	284	284	0	0	0	0	0	0	0	0	0	0
	その他	125	125	0	0	0	0	0	0	0	0	0	0
ピリダフェンチオン			～0.00002	～0.00004	～0.00006	～0.00010	～0.00014	～0.00020	～0.00060	～0.00100	～0.00140	～0.00200	0.00201～
	全体	589	580	2	7	0	0	0	0	0	0	0	0
	表流水	163	162	0	1	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	270	262	2	6	0	0	0	0	0	0	0	0
	その他	124	124	0	0	0	0	0	0	0	0	0	0
ピリプチカルブ			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	653	653	0	0	0	0	0	0	0	0	0	0
	表流水	173	173	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	315	315	0	0	0	0	0	0	0	0	0	0
	その他	132	132	0	0	0	0	0	0	0	0	0	0
ピロキロン			～0.0005	～0.0010	～0.0015	～0.0025	～0.0035	～0.0050	～0.0150	～0.0250	～0.0350	～0.0500	0.0501～
	全体	665	665	0	0	0	0	0	0	0	0	0	0
	表流水	176	176	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	35	35	0	0	0	0	0	0	0	0	0	0
	地下水	318	318	0	0	0	0	0	0	0	0	0	0
	その他	136	136	0	0	0	0	0	0	0	0	0	0
フィプロニル			～0.00005	～0.00010	～0.00015	～0.00020	～0.00025	～0.00030	～0.00035	～0.00040	～0.00045	～0.00050	0.00051～
	全体	666	666	0	0	0	0	0	0	0	0	0	0
	表流水	160	160	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	334	334	0	0	0	0	0	0	0	0	0	0
	その他	140	140	0	0	0	0	0	0	0	0	0	0
フェントロチオン (MEP)			～0.0001	～0.0002	～0.0003	～0.0005	～0.0007	～0.0010	～0.0030	～0.0050	～0.0070	～0.010	0.0101～
	全体	831	828	0	0	0	0	3	0	0	0	0	0
	表流水	217	217	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	37	37	0	0	0	0	0	0	0	0	0	0
	地下水	410	407	0	0	0	0	3	0	0	0	0	0
	その他	167	167	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
フェノカルブ (BPMC)			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	689	689	0	0	0	0	0	0	0	0	0	0
	表流水	174	174	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	330	330	0	0	0	0	0	0	0	0	0	0
	その他	152	152	0	0	0	0	0	0	0	0	0	0
フェリムゾン			～0.005	～0.010	～0.015	～0.020	～0.025	～0.030	～0.035	～0.040	～0.045	～0.050	0.051～
	全体	619	619	0	0	0	0	0	0	0	0	0	0
	表流水	167	167	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	29	29	0	0	0	0	0	0	0	0	0	0
	地下水	311	311	0	0	0	0	0	0	0	0	0	0
	その他	112	112	0	0	0	0	0	0	0	0	0	0
フェンチオン (MPP)			～0.00001	～0.00002	～0.00003	～0.00005	～0.00007	～0.00010	～0.00030	～0.00050	～0.00070	～0.00100	0.00101～
	全体	682	671	0	0	0	11	0	0	0	0	0	0
	表流水	168	167	0	0	0	1	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	336	326	0	0	0	10	0	0	0	0	0	0
	その他	144	144	0	0	0	0	0	0	0	0	0	0
フェントエート (PAP)			～0.00004	～0.00008	～0.00012	～0.00020	～0.00028	～0.00040	～0.00120	～0.00200	～0.00280	～0.00400	0.00401～
	全体	687	674	13	0	0	0	0	0	0	0	0	0
	表流水	167	166	1	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	333	322	11	0	0	0	0	0	0	0	0	0
	その他	155	154	1	0	0	0	0	0	0	0	0	0
フェントラザミド			～0.001	～0.002	～0.003	～0.004	～0.005	～0.006	～0.007	～0.008	～0.009	～0.010	0.011～
	全体	598	598	0	0	0	0	0	0	0	0	0	0
	表流水	148	148	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	294	294	0	0	0	0	0	0	0	0	0	0
	その他	124	124	0	0	0	0	0	0	0	0	0	0
フサライド			～0.001	～0.002	～0.003	～0.005	～0.007	～0.010	～0.030	～0.050	～0.070	～0.100	0.101～
	全体	780	780	0	0	0	0	0	0	0	0	0	0
	表流水	210	210	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	38	38	0	0	0	0	0	0	0	0	0	0
	地下水	388	388	0	0	0	0	0	0	0	0	0	0
	その他	144	144	0	0	0	0	0	0	0	0	0	0
ブタクロール			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	539	539	0	0	0	0	0	0	0	0	0	0
	表流水	147	147	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	35	35	0	0	0	0	0	0	0	0	0	0
	地下水	250	250	0	0	0	0	0	0	0	0	0	0
	その他	107	107	0	0	0	0	0	0	0	0	0	0
ブタミホス			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	677	677	0	0	0	0	0	0	0	0	0	0
	表流水	171	171	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	322	322	0	0	0	0	0	0	0	0	0	0
	その他	152	152	0	0	0	0	0	0	0	0	0	0
ブプロフェジン			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	725	725	0	0	0	0	0	0	0	0	0	0
	表流水	202	202	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	342	342	0	0	0	0	0	0	0	0	0	0
	その他	148	148	0	0	0	0	0	0	0	0	0	0
フルアジナム			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	641	641	0	0	0	0	0	0	0	0	0	0
	表流水	175	175	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	311	311	0	0	0	0	0	0	0	0	0	0
	その他	123	123	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
プレチラクロール			～0.0005	～0.0010	～0.0015	～0.0025	～0.0035	～0.0050	～0.0150	～0.0250	～0.0350	～0.0500	0.0501～
	全体	721	721	0	0	0	0	0	0	0	0	0	0
	表流水	182	182	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	348	348	0	0	0	0	0	0	0	0	0	0
	その他	157	157	0	0	0	0	0	0	0	0	0	0
プロシモン			～0.0009	～0.0018	～0.0027	～0.0045	～0.0063	～0.0090	～0.0270	～0.0450	～0.0630	～0.0900	0.0901～
	全体	578	578	0	0	0	0	0	0	0	0	0	0
	表流水	153	153	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	279	279	0	0	0	0	0	0	0	0	0	0
	その他	113	113	0	0	0	0	0	0	0	0	0	0
プロチオホス			～0.00007	～0.00014	～0.00021	～0.00035	～0.00049	～0.00070	～0.00210	～0.00350	～0.00490	～0.00700	0.00701～
	全体	476	475	0	0	0	0	1	0	0	0	0	0
	表流水	133	133	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	21	21	0	0	0	0	0	0	0	0	0	0
	地下水	230	229	0	0	0	0	1	0	0	0	0	0
	その他	92	92	0	0	0	0	0	0	0	0	0	0
プロピコナゾール			～0.0005	～0.0010	～0.0015	～0.0025	～0.0035	～0.0050	～0.0150	～0.0250	～0.0350	～0.0500	0.0501～
	全体	617	617	0	0	0	0	0	0	0	0	0	0
	表流水	156	156	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	308	308	0	0	0	0	0	0	0	0	0	0
	その他	121	121	0	0	0	0	0	0	0	0	0	0
プロピザミド			～0.0005	～0.0010	～0.0015	～0.0025	～0.0035	～0.0050	～0.0150	～0.0250	～0.0350	～0.0500	0.0501～
	全体	644	644	0	0	0	0	0	0	0	0	0	0
	表流水	166	166	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	320	320	0	0	0	0	0	0	0	0	0	0
	その他	126	126	0	0	0	0	0	0	0	0	0	0
プロベナゾール			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	687	687	0	0	0	0	0	0	0	0	0	0
	表流水	178	178	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	39	39	0	0	0	0	0	0	0	0	0	0
	地下水	342	342	0	0	0	0	0	0	0	0	0	0
	その他	128	128	0	0	0	0	0	0	0	0	0	0
プロモブチド			～0.0004	～0.0008	～0.0012	～0.0020	～0.0028	～0.0040	～0.0120	～0.0200	～0.0280	～0.0400	0.0401～
	全体	717	701	0	15	1	0	0	0	0	0	0	0
	表流水	185	184	0	1	0	0	0	0	0	0	0	0
	ダム湖沼	39	39	0	0	0	0	0	0	0	0	0	0
	地下水	339	325	0	13	1	0	0	0	0	0	0	0
	その他	154	153	0	1	0	0	0	0	0	0	0	0
ベノミル			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	619	619	0	0	0	0	0	0	0	0	0	0
	表流水	170	170	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	28	0	0	0	0	0	0	0	0	0	0
	地下水	299	299	0	0	0	0	0	0	0	0	0	0
	その他	122	122	0	0	0	0	0	0	0	0	0	0
ベンシクロン			～0.001	～0.002	～0.003	～0.005	～0.007	～0.010	～0.030	～0.050	～0.070	～0.100	0.101～
	全体	638	638	0	0	0	0	0	0	0	0	0	0
	表流水	162	162	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	304	304	0	0	0	0	0	0	0	0	0	0
	その他	138	138	0	0	0	0	0	0	0	0	0	0
ベンゾピシクロン			～0.009	～0.018	～0.027	～0.036	～0.045	～0.054	～0.063	～0.072	～0.081	～0.090	0.091～
	全体	571	571	0	0	0	0	0	0	0	0	0	0
	表流水	154	154	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	34	34	0	0	0	0	0	0	0	0	0	0
	地下水	270	270	0	0	0	0	0	0	0	0	0	0
	その他	113	113	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
ベンゾフェナップ			～0.00005	～0.00010	～0.00015	～0.00025	～0.00035	～0.00050	～0.00150	～0.00250	～0.00350	～0.00500	0.00501～
	全体	546	546	0	0	0	0	0	0	0	0	0	0
	表流水	145	145	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	250	250	0	0	0	0	0	0	0	0	0	0
	その他	119	119	0	0	0	0	0	0	0	0	0	0
ベンタゾン			～0.002	～0.004	～0.006	～0.010	～0.0140	～0.020	～0.060	～0.100	～0.140	～0.200	0.201～
	全体	725	725	0	0	0	0	0	0	0	0	0	0
	表流水	204	204	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	40	40	0	0	0	0	0	0	0	0	0	0
	地下水	346	346	0	0	0	0	0	0	0	0	0	0
	その他	135	135	0	0	0	0	0	0	0	0	0	0
ペンディメタリン			～0.001	～0.002	～0.003	～0.005	～0.007	～0.010	～0.030	～0.050	～0.070	～0.100	0.101～
	全体	681	669	0	12	0	0	0	0	0	0	0	0
	表流水	175	174	0	1	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	335	324	0	11	0	0	0	0	0	0	0	0
	その他	138	138	0	0	0	0	0	0	0	0	0	0
ベンフラカルブ			～0.0002	～0.0004	～0.0006	～0.0010	～0.0014	～0.0020	～0.0060	～0.0100	～0.0140	～0.0200	0.0201～
	全体	567	567	0	0	0	0	0	0	0	0	0	0
	表流水	146	146	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	28	28	0	0	0	0	0	0	0	0	0	0
	地下水	280	280	0	0	0	0	0	0	0	0	0	0
	その他	113	113	0	0	0	0	0	0	0	0	0	0
ベンフルラリン(ベスロジン)			～0.0008	～0.0016	～0.0024	～0.0040	～0.0056	～0.0080	～0.0240	～0.0400	～0.0560	～0.0800	0.0801～
	全体	570	567	3	0	0	0	0	0	0	0	0	0
	表流水	157	157	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	263	260	3	0	0	0	0	0	0	0	0	0
	その他	118	118	0	0	0	0	0	0	0	0	0	0
ベンフレセート			～0.007	～0.014	～0.021	～0.028	～0.035	～0.042	～0.049	～0.056	～0.063	～0.070	0.071～
	全体	462	462	0	0	0	0	0	0	0	0	0	0
	表流水	138	138	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	207	207	0	0	0	0	0	0	0	0	0	0
	その他	84	84	0	0	0	0	0	0	0	0	0	0
ホスチアゼート			～0.00005	～0.00010	～0.00015	～0.00025	～0.00035	～0.00050	～0.00150	～0.00250	～0.00350	～0.00500	0.00501～
	全体	593	592	0	0	0	0	1	0	0	0	0	0
	表流水	161	161	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	281	280	0	0	0	0	1	0	0	0	0	0
	その他	118	118	0	0	0	0	0	0	0	0	0	0
マラチオン(マラソン)			～0.007	～0.014	～0.021	～0.035	～0.049	～0.070	～0.21	～0.35	～0.49	～0.7	0.701～
	全体	728	728	0	0	0	0	0	0	0	0	0	0
	表流水	195	195	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	348	348	0	0	0	0	0	0	0	0	0	0
	その他	152	152	0	0	0	0	0	0	0	0	0	0
メコプロップ(MCPP)			～0.00050	～0.00100	～0.00150	～0.00250	～0.00350	～0.00500	～0.01500	～0.02500	～0.03500	～0.05000	0.05001～
	全体	617	617	0	0	0	0	0	0	0	0	0	0
	表流水	161	161	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	289	289	0	0	0	0	0	0	0	0	0	0
	その他	134	134	0	0	0	0	0	0	0	0	0	0
メソミル			～0.0003	～0.0006	～0.0009	～0.0015	～0.0021	～0.0030	～0.0090	～0.0150	～0.0210	～0.0300	0.0301～
	全体	648	648	0	0	0	0	0	0	0	0	0	0
	表流水	180	180	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	311	311	0	0	0	0	0	0	0	0	0	0
	その他	125	125	0	0	0	0	0	0	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
メタラキシル			～0.002	～0.004	～0.006	～0.010	～0.0140	～0.020	～0.060	～0.100	～0.140	～0.200	0.201～
	全体	705	705	0	0	0	0	0	0	0	0	0	0
	表流水	184	184	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	36	36	0	0	0	0	0	0	0	0	0	0
	地下水	328	328	0	0	0	0	0	0	0	0	0	0
	その他	157	157	0	0	0	0	0	0	0	0	0	0
メチダチオン (DMTP)			～0.00004	～0.00008	～0.00012	～0.00020	～0.00028	～0.00040	～0.00120	～0.00200	～0.00280	～0.00400	0.00401～
	全体	726	726	0	0	0	0	0	0	0	0	0	0
	表流水	189	189	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	26	26	0	0	0	0	0	0	0	0	0	0
	地下水	362	362	0	0	0	0	0	0	0	0	0	0
	その他	149	149	0	0	0	0	0	0	0	0	0	0
メトミノストロピン			～0.0004	～0.0008	～0.0012	～0.0020	～0.0028	～0.0040	～0.0120	～0.0200	～0.0280	～0.0400	0.0401～
	全体	574	574	0	0	0	0	0	0	0	0	0	0
	表流水	153	153	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	35	35	0	0	0	0	0	0	0	0	0	0
	地下水	274	274	0	0	0	0	0	0	0	0	0	0
	その他	112	112	0	0	0	0	0	0	0	0	0	0
メトリブジン			～0.003	～0.006	～0.009	～0.012	～0.015	～0.018	～0.021	～0.024	～0.027	～0.030	0.031～
	全体	582	582	0	0	0	0	0	0	0	0	0	0
	表流水	152	152	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	32	32	0	0	0	0	0	0	0	0	0	0
	地下水	285	285	0	0	0	0	0	0	0	0	0	0
	その他	113	113	0	0	0	0	0	0	0	0	0	0
メフェナセツト			～0.00009	～0.00018	～0.00027	～0.00045	～0.00063	～0.00090	～0.00270	～0.00450	～0.00630	～0.00900	0.00901～
	全体	785	769	0	16	0	0	0	0	0	0	0	0
	表流水	205	203	0	2	0	0	0	0	0	0	0	0
	ダム湖沼	37	37	0	0	0	0	0	0	0	0	0	0
	地下水	384	371	0	13	0	0	0	0	0	0	0	0
	その他	159	158	0	1	0	0	0	0	0	0	0	0
メプロニル			～0.001	～0.002	～0.003	～0.005	～0.007	～0.010	～0.030	～0.050	～0.070	～0.100	0.101～
	全体	645	645	0	0	0	0	0	0	0	0	0	0
	表流水	169	169	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	33	33	0	0	0	0	0	0	0	0	0	0
	地下水	313	313	0	0	0	0	0	0	0	0	0	0
	その他	130	130	0	0	0	0	0	0	0	0	0	0
モリネート			～0.00005	～0.00010	～0.00015	～0.00025	～0.00035	～0.00050	～0.00150	～0.00250	～0.00350	～0.00500	0.00501～
	全体	722	718	0	0	0	4	0	0	0	0	0	0
	表流水	193	192	0	0	0	1	0	0	0	0	0	0
	ダム湖沼	36	36	0	0	0	0	0	0	0	0	0	0
	地下水	335	332	0	0	0	3	0	0	0	0	0	0
	その他	158	158	0	0	0	0	0	0	0	0	0	0
水温(℃)			～10.0	～12.0	～14.0	～16.0	～18.0	～20.0	～22.0	～24.0	～26.0	～28.0	28.1～
	全体	7,033	55	276	576	1,229	1,767	2,174	815	71	49	18	3
	表流水	1,612	17	78	155	354	476	399	110	12	8	3	0
	ダム湖沼	266	5	10	13	20	58	106	46	2	3	3	0
	地下水	3,463	21	71	191	495	913	1,228	491	40	10	2	1
	その他	1,692	12	117	217	360	320	441	168	17	28	10	2
紫外線(UV)吸光度(50mmセル使用時)			～0.040	～0.080	～0.120	～0.160	～0.200	～0.240	～0.280	～0.320	～0.360	～0.400	0.401～
	全体	142	111	27	2	2	0	0	0	0	0	0	0
	表流水	50	32	16	0	2	0	0	0	0	0	0	0
	ダム湖沼	17	12	3	2	0	0	0	0	0	0	0	0
	地下水	54	51	3	0	0	0	0	0	0	0	0	0
	その他	21	16	5	0	0	0	0	0	0	0	0	0
侵食性遊離炭酸			～2.5	～5.0	～7.5	～10.0	～12.5	～15.0	～17.5	～20.0	～22.5	～25.0	25.1～
	全体	294	111	88	30	16	15	15	6	6	1	1	5
	表流水	52	23	24	2	0	1	2	0	0	0	0	0
	ダム湖沼	15	8	5	2	0	0	0	0	0	0	0	0
	地下水	141	40	31	19	13	10	10	5	6	1	1	5
	その他	86	40	28	7	3	4	3	1	0	0	0	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。

水質項目		計	区分										
生物(n/ml)			～10.0	～50.0	～100.0	～500.0	～1000.0	～5000.0	～10000.0	～50000.0	～100000.0	～500000.0	500000.1～
	全体	3	3	0	0	0	0	0	0	0	0	0	0
	表流水	2	2	0	0	0	0	0	0	0	0	0	0
	ダム湖沼	1	1	0	0	0	0	0	0	0	0	0	0
	地下水	0	0	0	0	0	0	0	0	0	0	0	0
	その他	0	0	0	0	0	0	0	0	0	0	0	0
アルカリ度			～10.0	～20.0	～30.0	～40.0	～50.0	～60.0	～70.0	～80.0	～90.0	～100.0	100.1～
	全体	982	20	126	173	249	160	119	55	33	22	11	14
	表流水	276	16	65	82	59	35	11	5	1	1	1	0
	ダム湖沼	63	3	12	21	15	4	4	1	1	1	1	0
	地下水	410	1	14	38	89	86	81	42	27	14	7	11
	その他	233	0	35	32	86	35	23	7	4	6	2	3
硫酸イオン			～5.0	～10.0	～20.0	～30.0	～40.0	～50.0	～60.0	～70.0	～80.0	～90.0	90.1～
	全体	550	113	170	141	61	42	9	4	3	4	0	3
	表流水	143	22	36	50	19	12	1	1	0	2	0	0
	ダム湖沼	33	6	16	5	4	1	1	0	0	0	0	0
	地下水	224	48	81	55	21	11	5	1	1	1	0	0
	その他	150	37	37	31	17	18	2	2	2	1	0	3
溶性ケイ酸			～5.0	～10.0	～20.0	～30.0	～40.0	～50.0	～60.0	～70.0	～80.0	～90.0	90.1～
	全体	129	1	5	26	23	13	18	19	14	7	3	0
	表流水	19	0	1	8	4	1	3	0	2	0	0	0
	ダム湖沼	4	0	1	3	0	0	0	0	0	0	0	0
	地下水	72	0	0	6	15	8	11	16	11	4	1	0
	その他	34	1	3	9	4	4	4	3	1	3	2	0

※大腸菌の平均値定性検査の結果は、1年の内に1度でも陽性であった場合は「陽性」に区分した。